

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	09-02-2026 13:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	09-02-2026 13:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	45 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Military Affairs
संगठन का नाम/Organisation Name	Indian Army
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	11016
वस्तु श्रेणी /Item Category	PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694 (Q2) , PVC Flat Cable, Aluminium Conductor with PVC Insulation and Sheath as per IS 694 (Q3) , XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) (Q2) , LED Batten (Q2) , LED Bulkhead Light (Q3) , LED Garden Light (V2) (Q2) , LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5) (Q3) , Self Ballasted LED Lamps (LED Bulb) (V3) Conforming to IS 16102 (Part 2) (Under BIS Scheme - II) (Q2) , LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3) (Q3) , Capacitors for Electric Fan Motors as per IS 1709 (V2) (Q3) , Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3) , Electrical Plugs (V2) ISI Marked to IS 1293 (Q2) , Piano Type Non Modular Domestic Electrical sockets - IS 1293 (Q3) , Non - Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3) , Electric Bells and Accessories as per IS 2268 (Q3) , Piano Type Non Modular Domestic Fan Regulator as per IS 11037 (Q3) , Piano Type Non Modular Electrical Switch Socket Combination as per IS 3854 and IS 1293 (Q3) , Plasticized PVC Tapes with Non-Thermosetting Adhesive for electrical purpose (V2) ISI marked to IS 7809 (Part 3/ Sec1) (Q2) , MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , Miniature Circuit Breakers Distribution Boards as per IS 13032 (Q3) , Electrical Terminals as per IS 8309 (Q3) , Heater Elements (Q3) , PVC Flat Cable, Copper Conductor with PVC Insulation and Sheath as per IS 694 (Q3) , LED Luminaire (Recessed Luminaire) (V3) Conforming to IS 10322 (Part 5/Section 2) (Q3)

बिड विवरण/Bid Details	
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	23 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) /OEM Average Turnover (Last 3 Years)	50 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष /Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/ MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/ Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/ Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	5
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
विगत प्रदर्शन / Past Performance	30 %
बिड से रिवर्स नीलामी सक्रिय किया/ Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/ RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/ Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/ Primary product category	LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3)

बिड विवरण/Bid Details	
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	Yes
Inspection to be carried out by Buyers own empanelled agency	Yes
Type Of Inspection	Post Dispatch
Name of the Empanelled Inspection Agency/ Authority	Board of Officers
Auto CRAC Days	60
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	90000

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	6

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई कटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

Commander Works Engineer (AF) Chandigarh
 HQ CWE AF Chandigarh, Department of Military Affairs, Indian Army, Ministry of Defence
 (Col Amit Bhat)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid

document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

4. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

5. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 30% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

8. Inspection of Stores by Nominated Inspection Authority / Agency of buyer or their authorized representatives

An independent third party Professional Inspection Body can help buyer in mitigating buyer's risk with pre-dispatch/post-dispatch inspection in order to ensure that equipment, components, solutions and documentation conform to contractual requirements. The buyer has a right to inspect goods in reasonable manner and within reasonable time at any reasonable place as indicated in contract. Inspection Fee/ Charges (as pre-greed between buyer and Inspection Agency) would be borne by the buyer as per their internal arrangement but may be recovered from the seller if the consignment failed to conform to contractual specification and got rejected by the Inspection Officer .If so requested and accepted by the seller , initially seller may pay for inspection charges as applicable and get the same reimbursed from buyer if consignment accepted by the Inspecting Officer . For reimbursement seller has to submit proof of payment to Inspection Agency.

Seller/OEM shall send a notice in writing / e-mail to the Inspecting officer / inspection agency specifying the place

of inspection as per contract and the Inspecting officer shall on receipt of such notice notify to the seller the date and time when the stores would be inspected. The seller shall, at his own expenses, afford to the Inspecting officer, all reasonable facilities as may be necessary for satisfying himself that the stores are being and or have been manufactured in accordance with the technical particulars governing the supply. The decision of the purchaser representative /inspection authority regarding acceptance / rejection of consignment shall be final and binding on the seller.

The Seller shall provide, without any extra charge, all materials, tools, labour and assistance of every kind which the Inspecting officer may demand of him for any test, and examination, other than special or independent test, which he shall require to be made on the seller's premises and the seller shall bear and pay all costs attendant thereon.

The seller shall also provide and deliver store / sample from consignment under inspection free of charge at any such place other than his premises as the Inspecting officer may specify for acceptance tests for which seller/OEM does not have the facilities or for special/ independent tests.

In the event of rejection of stores or any part thereof by the Inspecting officer basis testing outside owing to lack of test facility at sellers premises, the seller shall, on demand, pay to the buyer the costs incurred in the inspection and/or test. Cost of test shall be assessed at the rate charged by the Laboratory to private persons for similar work.

Inspector shall have the right to put all the stores or materials forming part of the same or any part thereof to such tests as he may like fit and proper as per QAP/governing specification. The seller shall not be entitled to object on any ground whatsoever to the method of testing adopted by the Inspecting officer.

Unless otherwise provided for in the contract, the quantity of the stores or materials expended in test will be borne by seller.

Inspecting officer is the Final Authority to Certify Performance / accept the consignment. The Inspecting officer's decision as regards the rejection shall be final and binding on the seller.

The seller shall if so required at his own expense shall mark or permit the Inspecting officer to mark all the approved stores with a recognised Government or purchaser's mark.

9. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (880 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	1.5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (880 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	300	30
2	*****	*****Amritsar	400	30
3	*****	*****CHANDIGARH	180	30

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (880 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	2.5
CONSTRUCTION	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (880 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	400	30
2	*****	*****Amritsar	300	30
3	*****	*****CHANDIGARH	180	30

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	4
CONSTRUCTION	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (200 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	200	30

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	6
CONSTRUCTION	Type of Insulation	Type C (HR)

Additional Specification Parameters - PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (200 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	200	30

PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (100 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type A
	No. of core	2
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 1
	Nominal Area of Conductor (in Sq.mm)	2.5
	Optional tape between the cores and outer sheath	Yes

Additional Specification Parameters - PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (100 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	100	30

PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (300 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type A
	No. of core	2
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 1
	Nominal Area of Conductor (in Sq.mm)	4.0
	Optional tape between the cores and outer sheath	Yes

Additional Specification Parameters - PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (300 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	300	30

PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (100 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type A
	No. of core	2
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 1
	Nominal Area of Conductor (in Sq.mm)	10.0
	Optional tape between the cores and outer sheath	Yes

Additional Specification Parameters - PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (100 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	100	30

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (90 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq mm)	16
	Number of core (in Nos)	4
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Additional Specification Parameters - XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (90 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, KEI, PLAZA, POLYCAB, GRANDLAY, GLOSTER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	90	30

LED Batten (238 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	10.0
	Length of LED Batten (Nominal) (in mm)	560.0
	Lamp Efficacy (Lumen / Watt), Minimum	100, 110 Or higher
	Warranty for free replacement (in Years)	2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate

Additional Specification Parameters - LED Batten (238 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	36	30
2	*****	*****CHANDIGARH	152	30
3	*****	*****Jalandhar	50	30

LED Batten (400 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	18.0
	Length of LED Batten (Nominal) (in mm)	1150.0

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Lamp Efficacy (Lumen / Watt), Minimum	100, 110 Or higher
	Warranty for free replacement (in Years)	2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate

Additional Specification Parameters - LED Batten (400 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	400	30

LED Batten (300 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	20.0
	Length of LED Batten (Nominal) (in mm)	1150.0
	Lamp Efficacy (Lumen / Watt), Minimum	100, 110 Or higher
	Warranty for free replacement (in Years)	2, 3 Or higher
CONSTRUCTIONAL	Housing Material	Polycarbonate

Additional Specification Parameters - LED Batten (300 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	300	30

LED Bulkhead Light (40 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Material	Plastic
	Protection	IP66
	Driver included	Yes
Performance Parameters	Life Time	50000.0 (hour)
	Protection class IEC	Safety class I (I)
	Luminous flux (system flux)	1000.0 (lumen)
Dimensions and Size	Depth	79.0 (millimeter)
	Length	181.0 (millimeter)
	Width	98.0 (millimeter)
Warranty	Warranty	1, 2 Or higher (year)

Additional Specification Parameters - LED Bulkhead Light (40 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	10	30
2	*****	*****CHANDIGARH	30	30

LED Garden Light (V2) (19 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Type of Garden Light	Bollard type with Pole and LED lantern/luminaire
	Material of Garden Lighting pole including lighting system (lantern/luminaire) (Note: Wherever GI, MS, CI materials used, materials shall be ISI Marked)	Aluminium casting
	Pole height including lantern/luminaire (in m)	1
	No.of lantern/luminaire with each pole (in m)	1
LIGHT SOURCE	Type of light source - BEE star rating of LED Bulb	SMD LED Chip
	LED Rating in each lantern/luminaire/lighting system (in Watts)	10.0
	LED Lamp/System efficacy in each lantern / luminaire (in lumen / watt)	? 105 and < 120
	In case of LED bulb - Cap designation of each lamp and holder in each lantern / luminaire	Not applicable (for SMP LED Chip)
PROTECTION	Automatic Lower / Higher Cut off voltage	Yes. Lower cut off 120 V, Higher cut off 300 V

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Protection against surges and transients - External	> / = 10 KV Or higher
THERMAL MANAGEMENT	Minimum Operating Temperature (in deg. C)	-10
	Maximum Operating Temperature (in deg. C)	50
LANTERN/LUMINAIRE - CONSTRUCTION	Impact resistance on diffuser material (in IK)	7
	Protection of the entire housing (in IP) Protection of the entire housing as per IS:10322 (Part 1):1982 latest	65
	Length of ISI marked three core connecting wire (Provided along with each lantern/luminiare) - (in m)	0.5
CERTIFICATIONS	Warranty for free replacement of lighting systems including lightsource (in years)	2
ADVANCE SAMPLE	Agreed to provide Advance Sample(s) for buyer's approval before commencement of supply. (hint: Applicable in case of orders placed against bid and not applicable in case of Direct Buying)	Yes

Additional Specification Parameters - LED Garden Light (V2) (19 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	4	30

क्र.सं./S.N o.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
2	*****	*****Jalandhar	15	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (10 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	50

Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (10 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	10	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (3 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	70

Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (3 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	3	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (11 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* [जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	90

Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (11 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
------------------------------	----------------------------------

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	11	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (5 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	120

Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (5 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	5	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (10 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	150

Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (10 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	10	30

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (5 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	250

Additional Specification Parameters - LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (5 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	5	30

Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (200 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Wattage (in Watts)	5.0
	BEE Star Rating	2 Star
	Type of LED Lamp Cap	B22d

Additional Specification Parameters - Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (200 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	100	30
2	*****	*****Jalandhar	100	30

Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (246 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Wattage (in Watts)	6.0
	BEE Star Rating	2 Star
	Type of LED Lamp Cap	B22d

Additional Specification Parameters - Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (246 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	146	30
2	*****	*****Jalandhar	100	30

Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (375 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Wattage (in Watts)	9.0
	BEE Star Rating	2 Star
	Type of LED Lamp Cap	B22d

Additional Specification Parameters - Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (375 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	130	30
2	*****	*****CHANDIGARH	245	30

Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (204 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Wattage (in Watts)	12.0
	BEE Star Rating	2 Star
	Type of LED Lamp Cap	B22d

Additional Specification Parameters - Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (204 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	21	30
2	*****	*****Amritsar	40	30
3	*****	*****CHANDIGARH	143	30

Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (310 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Wattage (in Watts)	15.0
	BEE Star Rating	2 Star
	Type of LED Lamp Cap	B22d

Additional Specification Parameters - Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (310 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	170	30
2	*****	*****Jalandhar	140	30

Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (100 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Wattage (in Watts)	20.0
	BEE Star Rating	2 Star
	Type of LED Lamp Cap	B22d

Additional Specification Parameters - Self Ballasted LED Lamps (LED Bulb) (V3) Conforming To IS 16102 (Part 2) (Under BIS Scheme - II) (100 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	100	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (46 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	36
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

Additional Specification Parameters - LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (46 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	8	30
2	*****	*****CHANDIGARH	16	30
3	*****	*****Jalandhar	22	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 /

Section 3) (54 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	45
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

Additional Specification Parameters - LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (54 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	13	30
2	*****	*****Jalandhar	41	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (38 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	60
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

Additional Specification Parameters - LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (38 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
------------------------------	----------------------------------

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	8	30
2	*****	*****Jalandhar	30	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (44 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	70
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

Additional Specification Parameters - LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (44 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	7	30
2	*****	*****Amritsar	14	30
3	*****	*****Jalandhar	23	30

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (32 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	90
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

Additional Specification Parameters - LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (32 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	4	30
2	*****	*****Jalandhar	28	30

Capacitors For Electric Fan Motors As Per IS 1709 (V2) (91 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Type of Capacitor	Self Healing Capacitor
	Rated Capacitance of the fan capacitor (µF)	2.5
	Terminal of Capacitor	Lead

Additional Specification Parameters - Capacitors For Electric Fan Motors As Per IS 1709 (V2) (91 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	EPCOS, UNIVERSAL, GENERAL CAPACITOR, KINJAL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	65	30
2	*****	*****CHANDIGARH	26	30

Capacitors For Electric Fan Motors As Per IS 1709 (V2) (50 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Type of Capacitor	Self Healing Capacitor
	Rated Capacitance of the fan capacitor (µF)	4.0
	Terminal of Capacitor	Lead

Additional Specification Parameters - Capacitors For Electric Fan Motors As Per IS 1709 (V2) (50 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	EPCOS, UNIVERSAL, GENERAL CAPACITOR, KINJAL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	50	30

Modular Piano Type Domestic Electrical Switches As Per IS 3854 (140 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Type of Switch	1 way switch
	Rated current	6A
	Rated voltage	240.0 (Volt)
Switch classification	No. of poles	Single pole
	According to type of terminal	Screw type terminal
	No. of modules	1 module
Construction	Current carrying material	Brass
	Color of switch body	white
Certification & standards	Warranty	1.0 (year)

Additional Specification Parameters - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (140 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	140	30

Electrical Plugs (V2) ISI Marked To IS 1293 (60 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Number of poles	2 Pole + Earth
	Rated Current (in A)	6 A
	Number of Pins	3
	Plug Classification	For Class 1 Appliances

Additional Specification Parameters - Electrical Plugs (V2) ISI Marked To IS 1293 (60 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	30	30
2	*****	*****CHANDIGARH	30	30

Electrical Plugs (V2) ISI Marked To IS 1293 (66 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Number of poles	2 Pole + Earth
	Rated Current (in A)	16 A

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Number of Pins	3
	Plug Classification	For Class 1 Appliances

Additional Specification Parameters - Electrical Plugs (V2) ISI Marked To IS 1293 (66 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	46	30
2	*****	*****CHANDIGARH	20	30

Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (569 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Current	6.0 (Ampère)
Generic	Socket type based on existence of shutter	Without Shutter
	Current Carrying Material	Brass
	According to type of Terminal	Screw Type Terminal
	Number of Modules	2
	Number of Poles	3
	Number of Pins	6
	Warranty	1.0 (year)

Additional Specification Parameters - Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (569 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	30	30
2	*****	*****Amritsar	70	30
3	*****	*****CHANDIGARH	69	30
4	*****	*****Jalandhar	400	30

Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (200 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Current	16.0 (Ampère)
Generic	Socket type based on existence of shutter	Without Shutter
	Current Carrying Material	Brass
	According to type of Terminal	Screw Type Terminal
	Number of Modules	2
	Number of Poles	3
	Number of Pins	6
	Warranty	1.0 (year)

Additional Specification Parameters - Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (200 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	200	30

Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (282 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Current	16.0 (Ampère)
Generic	Socket type based on existence of shutter	Without Shutter
	Current Carrying Material	Brass
	According to type of Terminal	Screw Type Terminal
	Number of Modules	1
	Number of Poles	2
	Number of Pins	3
	Warranty	1.0 (year)

Additional Specification Parameters - Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (282 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	12	30
2	*****	*****CHANDIGARH	40	30
3	*****	*****Jalandhar	230	30

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (790 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	6A
	Nature of Switch	1 way switch
	Rated voltage	230.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	surface type
Construction	Current carrying material	Copper
	Color of switch body	White
Certification & standards	Warranty	1.0 (year)

Additional Specification Parameters - Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (790 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	50	30
2	*****	*****Amritsar	90	30
3	*****	*****CHANDIGARH	235	30
4	*****	*****Jalandhar	415	30

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (533 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	16A
	Nature of Switch	1 way switch
	Rated voltage	240.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	surface type
Construction	Current carrying material	Brass
	Color of switch body	Others
Certification & standards	Warranty	1.0 (year)

Additional Specification Parameters - Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (533 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	13	30
2	*****	*****Amritsar	70	30
3	*****	*****CHANDIGARH	100	30
4	*****	*****Jalandhar	350	30

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (62 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	6A
	Nature of Switch	2 way switch
	Rated voltage	230.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	flush type
Construction	Current carrying material	Copper
	Color of switch body	White
Certification & standards	Warranty	1.0 (year)

Additional Specification Parameters - Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (62 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	42	30
2	*****	*****CHANDIGARH	20	30

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (67 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	6A
	Nature of Switch	bell push switch
	Rated voltage	230.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	surface type
Construction	Current carrying material	Copper
	Color of switch body	White
Certification & standards	Warranty	1.0 (year)

Additional Specification Parameters - Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (67 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	9	30
2	*****	*****CHANDIGARH	20	30
3	*****	*****Jalandhar	38	30

Electric Bells And Accessories As Per IS 2268 (128 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Product ISI marked	NO - But conforming to IS:2268
	Type of bell	Ding Dong type

Additional Specification Parameters - Electric Bells And Accessories As Per IS 2268 (128 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	18	30
2	*****	*****Amritsar	13	30
3	*****	*****CHANDIGARH	57	30
4	*****	*****Jalandhar	40	30

Piano Type Non Modular Domestic Fan Regulator As Per IS 11037 (52 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	BIS Marking	Yes
	Rated voltage	230.0 (Volt)
	Type of Regulator	socket size
	No of steps	5
Construction	Color of regulator body	Off-white
Certification & standards	Test report to be submitted to the Buyer on Demand	Yes

Additional Specification Parameters - Piano Type Non Modular Domestic Fan Regulator As Per IS 11037 (52 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	24	30
2	*****	*****Amritsar	28	30

Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 (150 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	6A
	Rated voltage	240.0 (Volt)
	Combination with Junction Box	Without Box
Construction	According to type of terminal	Screw type terminal
	Current carrying material	Brass
	Color of switch body	White
Certification & standards	Warranty	1.0 (year)

Additional Specification Parameters - Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 (150 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	50	30
2	*****	*****Jalandhar	100	30

Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 (120 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	16A

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated voltage	240.0 (Volt)
	Combination with Junction Box	Without Box
Construction	According to type of terminal	Screw type terminal
	Current carrying material	Brass
	Color of switch body	White
Certification & standards	Warranty	1.0 (year)

Additional Specification Parameters - Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 (120 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	HAVELL'S, ANCHOR, HPL, LEGRAND, PHILIPS, GOLD MEDAL, INDOASIAN, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	20	30
2	*****	*****Jalandhar	100	30

Plasticized PVC Tapes With Non-Thermosetting Adhesive For Electrical Purpose (V2) ISI Marked To IS 7809 (Part 3/ Sec1) (20 rolls)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Specification	Governing Specification	As per IS 7809 (Part 3/ Sec1)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Classification	Type	General Purpose Type (suitable for application at temperature above 0°C, and designated as F-PVCp/90/0/Tp)
Dimension	Length of tape in a roll (in metre)	25
	Width of tape (in mm) (Tolerance as per clause 6.2.1 of the IS 7809 (part1))	15
	Thickness (in mm) (Tolerance \pm 0.025 mm)	0.125

Additional Specification Parameters - Plasticized PVC Tapes With Non-Thermosetting Adhesive For Electrical Purpose (V2) ISI Marked To IS 7809 (Part 3/ Sec1) (20 rolls)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	ANCHOR, KINJAL, GOLD MEDAL, HPL, PROTEX

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	20	30

Plasticized PVC Tapes With Non-Thermosetting Adhesive For Electrical Purpose (V2) ISI Marked To IS 7809 (Part 3/ Sec1) (175 rolls)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Specification	Governing Specification	As per IS 7809 (Part 3/ Sec1)
Classification	Type	General Purpose Type (suitable for application at temperature above 0°C, and designated as F-PVCp/90/0/Tp)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Dimension	Length of tape in a roll (in metre)	25
	Width of tape (in mm) (Tolerance as per clause 6.2.1 of the IS 7809 (part1))	20
	Thickness (in mm) (Tolerance \pm 0.025 mm)	0.125

Additional Specification Parameters - Plasticized PVC Tapes With Non-Thermosetting Adhesive For Electrical Purpose (V2) ISI Marked To IS 7809 (Part 3/ Sec1) (175 rolls)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	ANCHOR, KINJAL, GOLD MEDAL, HPL, PROTEX

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	45	30
2	*****	*****Jalandhar	130	30

Plasticized PVC Tapes With Non-Thermosetting Adhesive For Electrical Purpose (V2) ISI Marked To IS 7809 (Part 3/ Sec1) (240 rolls)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Specification	Governing Specification	As per IS 7809 (Part 3/ Sec1)
Classification	Type	General Purpose Type (suitable for application at temperature above 0°C, and designated as F-PVCp/90/0/Tp)
Dimension	Length of tape in a roll (in metre)	25

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Width of tape (in mm) (Tolerance as per clause 6.2.1 of the IS 7809 (part1))	25
	Thickness (in mm) (Tolerance \pm 0.025 mm)	0.125

Additional Specification Parameters - Plasticized PVC Tapes With Non-Thermosetting Adhesive For Electrical Purpose (V2) ISI Marked To IS 7809 (Part 3/ Sec1) (240 rolls)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	ANCHOR, KINJAL, GOLD MEDAL, HPL

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	70	30
2	*****	*****Amritsar	30	30
3	*****	*****Jalandhar	140	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (12 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	16

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (12 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Type of Curve of MCB	'C' curve should be mentioned on MCB
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	12	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (18 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	230 / 415 V, AC

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (18 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	18	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (18 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (18 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S, HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	2	30
2	*****	*****Jalandhar	16	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (74 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	6
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (74 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	50	30
2	*****	*****Jalandhar	24	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (78 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
---------------------	-------------------------------------	---

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	10
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (78 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Type of Curve of MCB ' '	C' curve should be mentioned on MCB
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	8	30
2	*****	*****CHANDIGARH	40	30
3	*****	*****Jalandhar	30	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (81 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	16
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (81 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	11	30
2	*****	*****CHANDIGARH	20	30
3	*****	*****Jalandhar	50	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (89 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	20
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (89 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	4	30
2	*****	*****CHANDIGARH	40	30
3	*****	*****Jalandhar	45	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (92 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	25
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (92 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Type of Curve of MCB	'C' curve should be mentioned on MCB

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	2	30
2	*****	*****Jalandhar	90	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (25 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* [जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (25 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Type of Curve of MCB	'C' curve should be mentioned on MCB
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	3	30
2	*****	*****Jalandhar	22	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (12 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (12 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	12	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (40 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	6
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (40 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	40	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (24 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	20
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (24 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	24	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (8 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	25
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (8 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	8	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (85 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
---------------------	-------------------------------------	---

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (85 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	15	30
2	*****	*****CHANDIGARH	30	30
3	*****	*****Jalandhar	40	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (54 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (54 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषीती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषीती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	4	30
2	*****	*****CHANDIGARH	20	30
3	*****	*****Jalandhar	30	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (14 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	4 P with 3 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (14 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	10	30
2	*****	*****Jalandhar	4	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (18 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	4 P with 3 PP
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Additional Specification Parameters - MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (18 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Type of Curve of MCB	'C' curve should be mentioned on MCB
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	3	30
2	*****	*****CHANDIGARH	15	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (4 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	63A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (4 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%lcu

Specification Parameter Name	Bid Requirement (Allowed Values)
Marking of brand name/Cat part no	Marking should be embossed rather than sticker paste on item. It should be as per IS-13947
Date and year of manufacturing	Manufacturing date and year should be latest and same is mentioned on box of the items.
Lab Test certificate	Lab test certificate should not be too old.
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	1	30
2	*****	*****Amritsar	3	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Marking of brand name/Cat part no	Marking should be embossed rather than sticker paste on item. It should be as per IS-13947
Date and year of manufacturing	Manufacturing date and year should be latest and same is mentioned on box of the items.
Lab Test certificate	Lab test certificate should not be too old.
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	125A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	16 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषीती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषीती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	2	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (3 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (3 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषीती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषीती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	1	30
2	*****	*****CHANDIGARH	2	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषीती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषीती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	1	30

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
2	*****	*****CHANDIGARH	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local

Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)**तकनीकी विशिष्टियाँ /Technical Specifications**

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	160A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	200A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	1	30
2	*****	*****CHANDIGARH	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	250A

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%lcu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	320A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Voltage	415 volt 50 Hz

Additional Specification Parameters - Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Service breaking capacity	100%Icu
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	1	30

Miniature Circuit Breakers Distribution Boards As Per IS 13032 (3 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Rated voltage of MCB Board (in Volts)	415
	Number of ways (in Nos)	4
	Rating of the Busbar (in Ampere)	100
	Material of Busbar	Copper
CONSTRUCTION	Material Of MCB Board Boxes	Mild Steel - Properly pretreated and stove enameled/Powder Coated
	Thickness of material (in mm)	1.4 mm (MS sheet)
	Enclosure - Degree of Protection	IP 43

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Method of operating MCB's	Double Door (after opening of top cover)
	Suitable to accommodates specified Number of poles	"Three Pole MCBs as out going and FP MCB with 3 Protected pole as incoming"

Additional Specification Parameters - Miniature Circuit Breakers Distribution Boards As Per IS 13032 (3 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	LEGRAND, ABB, L&T, SCHNEIDER, INDOASIAN, C&S,HAVELLS

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	3	30

Electrical Terminals As Per IS 8309 (13 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Designation / Stud hole (in mm)	CAA- 25/10.2
	Designation /Stud hole (in mm) - For XLPE Cables	CAAX-25/8.4

Additional Specification Parameters - Electrical Terminals As Per IS 8309 (13 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	DOWELL's, ASCON, Ya-Net, HEX, ENER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	13	30

Electrical Terminals As Per IS 8309 (79 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Designation / Stud hole (in mm)	Not applicable
	Designation /Stud hole (in mm) - For XLPE Cables	CAAX-35/10.5

Additional Specification Parameters - Electrical Terminals As Per IS 8309 (79 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	DOWELL's, ASCON, Ya-Net, HEX, ENER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	16	30
2	*****	*****CHANDIGARH	63	30

Electrical Terminals As Per IS 8309 (66 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Designation / Stud hole (in mm)	CAA-50/10.2
	Designation /Stud hole (in mm) - For XLPE Cables	CAAX- 50/10.5

Additional Specification Parameters - Electrical Terminals As Per IS 8309 (66 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	DOWELL's, ASCON, Ya-Net, HEX, ENER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	16	30
2	*****	*****CHANDIGARH	50	30

Electrical Terminals As Per IS 8309 (50 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Designation / Stud hole (in mm)	CAA-70/8.2
	Designation /Stud hole (in mm) - For XLPE Cables	CAAX-70/13.0

Additional Specification Parameters - Electrical Terminals As Per IS 8309 (50 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	DOWELL's, ASCON, Ya-Net, HEX, ENER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	11	30
2	*****	*****CHANDIGARH	39	30

Electrical Terminals As Per IS 8309 (26 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Designation / Stud hole (in mm)	CAA- 95/10.2
	Designation /Stud hole (in mm) - For XLPE Cables	CAAX- 95/13.0

Additional Specification Parameters - Electrical Terminals As Per IS 8309 (26 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	DOWELL's, ASCON, Ya-Net, HEX, ENER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	6	30
2	*****	*****CHANDIGARH	20	30

Electrical Terminals As Per IS 8309 (8 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Designation / Stud hole (in mm)	CAA-120/10.2
	Designation /Stud hole (in mm) - For XLPE Cables	CAAX- 120/13.0

Additional Specification Parameters - Electrical Terminals As Per IS 8309 (8 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	DOWELL's, ASCON, Ya-Net, HEX, ENER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	8	30

Electrical Terminals As Per IS 8309 (16 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Designation / Stud hole (in mm)	Not applicable
	Designation /Stud hole (in mm) - For XLPE Cables	CAAX-185/17.0

Additional Specification Parameters - Electrical Terminals As Per IS 8309 (16 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	DOWELL's, ASCON, Ya-Net, HEX, ENER

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	6	30
2	*****	*****CHANDIGARH	10	30

Heater Elements (20 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Material	Fin Material	Stainless Steel
	Tubing	Stainless Steel
Power	Wattage(Watt)	1000-2000
Warranty	Warranty in year	2, 3, 4, 5 Or higher (year)
Certification & Test Report	ISO Certified	Yes

Additional Specification Parameters - Heater Elements (20 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Wattage	1500

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	20	30

Heater Elements (20 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Material	Fin Material	Stainless Steel
	Tubing	Stainless Steel
Power	Wattage(Watt)	1000-2000
Warranty	Warranty in year	1, 2, 3, 4, 5 Or higher (year)
Certification & Test Report	ISO Certified	Yes

Additional Specification Parameters - Heater Elements (20 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Wattage	2000

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	20	30

PVC Flat Cable, Copper Conductor With PVC Insulation And Sheath As Per IS 694 (500 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C (HR)
	No. of core	2
	Conductor material (Complying with IS:8130:1984 latest)	Tinned Copper, Plain copper
	Nominal Area of Conductor (in Sq.mm)	0.75
	Optional tape between the cores and outer sheath	Yes, No

Additional Specification Parameters - PVC Flat Cable, Copper Conductor With PVC Insulation And Sheath As Per IS 694 (500 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	500	30

PVC Flat Cable, Copper Conductor With PVC Insulation And Sheath As Per IS 694 (200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C (HR)
	No. of core	3
	Conductor material (Complying with IS:8130:1984 latest)	Plain copper
	Nominal Area of Conductor (in Sq.mm)	2.5
	Optional tape between the cores and outer sheath	No

Additional Specification Parameters - PVC Flat Cable, Copper Conductor With PVC Insulation And Sheath As Per IS 694 (200 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	KEI, POLYCAB, HAVELLS, FINOLEX, PLAZA, HPL, STEP, ANCHOR

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Jalandhar	200	30

LED Luminaire (Recessed Luminaire) (V3) Conforming To IS 10322 (Part 5/Section 2) (10 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	Rating of Recess type LED Luminaire/System Wattage/Rated Power (in Watt)	24
	Colour temperature (in K) (+/- 500 K)	6500
	Light Intensity (System Lumens) (in lm/watt) (hint: Total Lumen Calculation: Example: 3 W LED Rating x 80 Lumen/Watt = 240 Lumens, 3 W LED Rating x 90 Lumen / Watt = 270 Lumens, 3 W LED Rating x 100 Lumen/Watt = 300 Lumens)	100
	LED Chip Efficacy (in lm/watt)	>/=130
	Shape of the Fixture	Square
	Size of the Fixture	600 mm x 600 mm
CONSTRUCTION	Number of electronic control gear (power supplies)	1

Additional Specification Parameters - LED Luminaire (Recessed Luminaire) (V3) Conforming To IS 10322 (Part 5/Section 2) (10 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Amritsar	10	30

LED Garden Light (V2) (10 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ / Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Type of Garden Light	Bollard type with Pole and LED lantern/luminaire, Architectural design with pole and LED lantern/luminaire, LED post top lantern/luminaire with pole
	Material of Garden Lighting pole including lighting system (lantern/luminaire) (Note: Wherever GI, MS, CI materials used, materials shall be ISI Marked)	Aluminium casting, Galvanised Iron, Mild steel, Cast iron, LED post top with out pole. Hence not applicable
	Pole height including lantern/luminaire (in m)	0.5, 1, 1.5, 3, 4, 5, 6, 7, 8, without pole
	No.of lantern/luminaire with each pole (in m)	1, 2, 3, 4, 5, LED post top with out pole. Hence not applicable
LIGHT SOURCE	Type of light source - BEE star rating of LED Bulb	SMD LED Chip
	LED Rating in each lantern/luminaire/lighting system (in Watts)	15.0
	LED Lamp/System efficacy in each lantern / luminaire (in lumen / watt)	? 105 and < 120
	In case of LED bulb - Cap designation of each lamp and holder in each lantern / luminaire	Not applicable (for SMP LED Chip)
PROTECTION	Automatic Lower / Higher Cut off voltage	Yes. Lower cut off 120 V, Higher cut off 300 V
	Protection against surges and transients - External	> / = 10 KV, No Or higher
THERMAL MANAGEMENT	Minimum Operating Temperature (in deg. C)	-10
	Maximum Operating Temperature (in deg. C)	50
LANTERN/LUMINAIRE - CONSTRUCTION	Impact resistance on diffuser material (in IK)	0
	Protection of the entire housing (in IP) Protection of the entire housing as per IS:10322 (Part 1):1982 latest	65

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Length of ISI marked three core connecting wire (Provided along with each lantern/luminiare) - (in m)	0.5
CERTIFICATIONS	Warranty for free replacement of lighting systems including lightsource (in years)	1
ADVANCE SAMPLE	Agreed to provide Advance Sample(s) for buyer's approval before commencement of supply. (hint: Applicable in case of orders placed against bid and not applicable in case of Direct Buying)	No

Additional Specification Parameters - LED Garden Light (V2) (10 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Accepted brands/Makes	BAJAJ, HAVELL'S, ORIENT, CROMPTON GREAVES, SURYA, WIPRO

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****CHANDIGARH	10	30

Special terms and conditions-Version:1 effective from 11-11-2025 for category Self Ballasted LED Lamps (LED Bulb) (V3) Conforming to IS 16102 (Part 2) (Under BIS Scheme - II)

- The marking, dimensions and emission (radiated and conducted) of radio frequency disturbances of Self Ballasted LED Lamps (LED Bulb) shall conform to the IS 16102 (Part 2).

Special terms and conditions-Version:1 effective from 29-08-2025 for category Capacitors for Electric Fan Motors as per IS 1709 (V2)

- Presently, the products under this category are not covered under mandatory BIS licensing scheme. Hence, both ISI Marked and non-ISI Marked products may be available in this category. However, if a buyer intends to procure ISI Marked products, buyer may, at his discretion, opt for the same by indicating the requirement in the bid, after taking into account the number of valid licenses issued under the standard. In such cases, buyer shall verify a valid BIS License as per the applicable governing standard at the time of evaluation of bid and check the ISI marking on the products at the time of receipt of material before issuing of CRAC.

The valid BIS license status of sellers may be viewed by buyer from the below link:

<https://www.manakonline.in/MANAK/ApplicationLicenceRelatedrpt>

or

https://www.services.bis.gov.in/php/BIS_2.0/bisconnect/knowyourstandards/indian_standards/isdetails

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/**Buyer Added Bid Specific Terms and Conditions**

1. **Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Inspection**

Nominated Inspection Agency: On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:

Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC):

By manufacturer itself

Post Receipt Inspection at consignee site before acceptance of stores:
Check by board of officer nominated by HoD/Buyer

3. **Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

Col Amit Bhat, Commander Works Engineer (AF) Chandigarh
payable at
Chandigarh

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

4. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Fixed Deposit Receipt also (besides PBG which is allowed as per GeM GTC). FDR should be made out or pledged in the name of

Col Amit Bhat, Commander Works Engineer (AF) Chandigarh
A/C (Name of the Seller). The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledgee. For release of Security Deposit, the FDR will be released in favour of bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Successful Bidder has to upload scanned copy of the FDR document in place of PBG and has to ensure delivery of hard copy of Original FDR to the Buyer within 15 days of award of contract.

5. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

6. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

7. Certificates

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

8. Certificates

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

9. Certificates

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

10. Turnover

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

11. Turnover

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

12. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.

4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने

व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा |/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---