

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	14-02-2026 17:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	14-02-2026 17:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Military Affairs
संगठन का नाम/Organisation Name	Indian Army
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	10161
वस्तु श्रेणी /Item Category	LED Luminaire for High Bay Lighting , LED Luminaire for Floodlight (V2) Conforming to IS 10322 (Part 5/Section 5) , LED Luminaire (Recessed Luminaire) (V3) Conforming to IS 10322 (Part 5/Section 2) , XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 , LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3) , LED Batten , Xlpe Cables, Category C2 - FR - LSH, for Working Voltages From 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2) , PVC Copper Cable Single Core and Multi Core Circular Sheathed Cable with Rigid Conductor (V2) as per IS 694 , LED FLAME PROOF HIGHT FITTING 200W , SOLAR ALL IN ONE 60W 125LPW 100WP 42AH , LED FLAME PROOF FOR TWIN T8 TUBE 20WATT
GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS	LED FLAME PROOF FOR TWIN T8 TUBE 20WATT
GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS	LED Luminaire for Flood Light, Flame Proof (V2), High Mast Lighting Tower for large area with LED Flood Lighting System
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	<ul style="list-style-type: none"> LED Batten
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	50 Lakh (s)

बिड विवरण/Bid Details	
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)/OEM Average Turnover (Last 3 Years)	600 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	2
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	10
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
विगत प्रदर्शन /Past Performance	10 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	LED Batten
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days

बिड विवरण/Bid Details

निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/ Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/ Arbitration Clause	No
सुलह खंड/ Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	1200000

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%)/ePBG Percentage(%)	1.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	3

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

AGE E/M
GARRISON ENGINEER I DM VISKHAPATNAM, Department of Military Affairs, Indian Army, Ministry of Defence
(Santosh Kumar Singh)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20

मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
4. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company

and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

5. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 10% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Pre Bid Detail(s)

मूल्य भिन्नता खंड दस्तावेज़/Pre-Bid Date and Time	प्री-बिड स्थान/Pre-Bid Venue
07-02-2026 10:00:00	Garrison Engineer Independent Dockyard Maintenance Visakhapatnam (AP) - 530014

LED Luminaire For High Bay Lighting (118 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Installation and commissioning	Yes

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Scope of installation and commissioning	Installation and commissioning includes mounting of lights on roof hooks/fixture and making electrical connections to make the light functional. Wiring is not in scope.
RATINGS	Operating input voltage range (in Volts)	140 to 300
	Luminaire System Wattge (in Watts)	200
	Luminaire System Efficacy - Lumen output - (Lumen/watt)	? 120
	Color Temperature (CCT) +/- 500 K (in Kelvin)	5500 K
	Colour Rendering Index (CRI) (in % age)	? 70
	Power Factor (PF)	? 0.95 at full load
	Ingress Protection (IP) Rating of Luminaire (agreed to furnish test certificates to buyer / consignee on demand)	IP 65
	Impact resistance (If claimed "Yes" - agreed to furnish test certificates to buyer / consignee on demand)	Yes. IK07 (as per IEC 62262:2002)
	Minimum operating temperature range (in deg. C)	-10 to 0
Maximum operating temperature range (in deg. C)	45.0 - 60.0 Or higher	
SAFETY	The luminaire shall be protected against surges and transients (Internal)	? 5 KV
	The luminaire shall be protected against surges and transients (External)	? 10 KV
	Flame/Fire proof compliance (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	Fire retardant Class - FV-0 (as per IS:11731 Part-II)
	Other compliacne (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	No
CONSTRUCTION	Shape of Luminaire	Round

विवरण/Specification	विशिष्ट का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of mounting	Metallic adjustable Brackets with Eye Bolt
	Installation height range from floor level (in m) - Must declare	9
	Optic Lens	Yes. Polycarbonate-UV stabilised
	Type of Control Gear	Constant Current
	Number of electronic control gear on each luminaire (power supplies) - (in Nos.)	1
	Luminaire fitted with connecting cables for input power	ISI Marked 3 Core cable for input power (Length:250 mm)
	Accessories for each luminaire	Metallic adjustable Brackets (Stainless steel)
MARKING	Marking/Identification details on inside of each luminaire and outside of each packing box	Manufacturer's Name
	Marking/Identification details on each control gear	Manufacturer's Name
CERTIFICATIONS	Warranty period (in Months)	24, 36, 48, 60 Or higher
	Availability of test reports from Central Govt. Lab/NABL/ILAC accredited laboratory to prove conformity of the specification	No
	Agreed to furnish LM 79 , LM 80 reports from Central Government lab/NABL/ILAC accredited lab	Yes as per IS:16106:2012 latest and as per IS:16105:2012 latest
	Agreed to furnish TM 21 report from Central Government lab/NABL/ILAC accredited lab	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	118	45

LED Luminaire For High Bay Lighting (150 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Installation and commissioning	No
	Scope of installation and commissioning	Not applicable
RATINGS	Operating input voltage range (in Volts)	140 to 270
	Luminaire System Wattge (in Watts)	150
	Luminaire System Efficacy - Lumen output - (Lumen/watt)	? 120
	Color Temperature (CCT) +/- 500 K (in Kelvin)	6000 K
	Colour Rendering Index (CRI) (in % age)	? 70
	Power Factor (PF)	? 0.95 at full load
	Ingress Protection (IP) Rating of Luminaire (agreed to furnish test certificates to buyer / consignee on demand)	IP 65
	Impact resistance (If claimed "Yes" - agreed to furnish test certificates to buyer / consignee on demand)	Yes. IK07 (as per IEC 62262:2002)
	Minimum operating temperature range (in deg. C)	-10 to 0
	Maximum operating temperature range (in deg. C)	50.0 - 60.0 Or higher

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
SAFETY	The luminaire shall be protected against surges and transients (Internal)	? 5 KV
	The luminaire shall be protected against surges and transients (External)	? 10 KV
	Flame/Fire proof compliance (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	No
	Other compliacne (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	No
CONSTRUCTION	Shape of Luminaire	Round
	Type of mounting	Metallic adjustable Brackets with Eye Bolt
	Installation height range from floor level (in m) - Must declare	9
	Optic Lens	Yes. Polycarbonate-UV stabilised
	Type of Control Gear	Constant Current
	Number of electronic control gear on each luminaire (power supplies) - (in Nos.)	1
	Luminaire fitted with connecting cables for input power	ISI Marked 3 Core cable for input power (Length:250 mm)
Accessories for each luminaire	Metallic adjustable Brackets (Stainless steel), SS Eye Bolts (as per IS:4190:1984 latest), Set of Bolt,Nut, Washers (SS), Die cast aluminium brackets, Metallic Adjustable Brackets (Stainless Steel) provided along with the fixtures for ceiling mounted high bay light fixtures	
MARKING	Marking/Identification details on inside of each luminaire and outside of each packing box	Manufacturer's Name, Model Number, Serial Number, Month and year of manufacturing, Voltage, System Wattage
	Marking/Identification details on each control gear	Manufacturer's Name, Model Number
CERTIFICATIONS	Warranty period (in Months)	24, 36, 48, 60 Or higher

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Availability of test reports from Central Govt. Lab/NABL/ILAC accredited laboratory to prove conformity of the specification	No
	Agreed to furnish LM 79 , LM 80 reports from Central Government lab/NABL/ILAC accredited lab	Yes as per IS:16106:2012 latest and as per IS:16105:2012 latest
	Agreed to furnish TM 21 report from Central Government lab/NABL/ILAC accredited lab	No

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	150	45

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (100 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	200

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	100	45

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (33 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	300

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	33	45

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (47 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	350

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	47	45

LED Luminaire For Floodlight (V2) Conforming To IS 10322 (Part 5/Section 5) (80 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating/System Wattage/Rated Power (in Watts)	250

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	80	45

LED Luminaire (Recessed Luminaire) (V3) Conforming To IS 10322 (Part 5/Section 2) (50 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	Rating of Recess type LED Luminaire/System Wattage/Rated Power (in Watt)	40

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Colour temperature (in K) (+/- 500 K)	6500
	Light Intensity (System Lumens) (in lm/watt) (hint: Total Lumen Calculation: Example: 3 W LED Rating x 80 Lumen/Watt = 240 Lumens, 3 W LED Rating x 90 Lumen / Watt = 270 Lumens, 3 W LED Rating x 100 Lumen/Watt = 300 Lumens)	100
	LED Chip Efficacy (in lm/watt)	>/=130
	Shape of the Fixture	Linear/Rectangular
	Size of the Fixture	300 mm x 1200 mm
CONSTRUCTION	Number of electronic control gear (power supplies)	2

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	50	45

LED Luminaire (Recessed Luminaire) (V3) Conforming To IS 10322 (Part 5/Section 2) (99 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	Rating of Recess type LED Luminaire/System Wattage/Rated Power (in Watt)	36

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Colour temperature (in K) (+/- 500 K)	6500
	Light Intensity (System Lumens) (in lm/watt) (hint: Total Lumen Calculation: Example: 3 W LED Rating x 80 Lumen/Watt = 240 Lumens, 3 W LED Rating x 90 Lumen / Watt = 270 Lumens, 3 W LED Rating x 100 Lumen/Watt = 300 Lumens)	100
	LED Chip Efficacy (in lm/watt)	>/=130
	Shape of the Fixture	Square
	Size of the Fixture	600 mm x 600 mm
CONSTRUCTION	Number of electronic control gear (power supplies)	1

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	99	45

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (500 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	300
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	500	45

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (500 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	400
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	500	45

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (500 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	240
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	500	45

XLPE Cable For Working Voltages Up To And Including 1.1 KV As Per IS 7098 (Part 1) (593 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	C2 - FR-LSH
	Nominal Area of Conductor (in Sq mm)	35
	Number of core (in Nos)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Not applicable

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	593	45

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (30 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	400A
	No of poles/Protected poles(PP)	4 Pole

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Short circuit capacity (in KA)	35 KA
	Breaking current (in KA)	36 KA
	Rated Voltage	240 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	30	45

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (35 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	250A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	35 KA
	Breaking current (in KA)	35 KA
	Rated Voltage	240 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	35	45

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (40 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	160A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	35 KA
	Breaking current (in KA)	25 KA
	Rated Voltage	220VDC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	40	45

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (60 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Current (in Ampere)	160A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	60	45

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (60 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	415 volt 50 Hz

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	60	45

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (35 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	YES
	Rated Current (in Ampere)	400A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	415 volt 50 Hz

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	35	45

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (52 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	120
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	52	45

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (150 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
---------------------	-------------------------------------	---

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	150
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	150	45

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (63 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
---------------------	-------------------------------------	---

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	200
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	63	45

LED Batten (1063 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	LED Batten Rating (in Watts)	20.0

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Length of LED Batten (Nominal) (in mm)	1150.0
	Lamp Efficacy (Lumen / Watt), Minimum	100, 110 Or higher
	Warranty for free replacement (in Years)	3 Or higher
CONSTRUCTIONAL	Housing Material	Aluminium

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	1063	45

Xlpe Cables, Category C2 - FR - LSH, For Working Voltages From 3.3 KV Up To And Including 33 KV As Per IS 7098 (Part 2) (500 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Types of cable	Three-core armoured, screened
	Voltage Grade	Earthed systems: 6.35/11 kV
	Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same)	Yes

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest	Aluminium
	Outer sheath (Type ST2)	PVC
	"Nominal Cross Sectional Area of Conductor	95
CONSTRUCTIONAL	Armouring	Galvanized formed wires armoured
	Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest	Wooden drum

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	500	45

Xlpe Cables, Category C2 - FR - LSH, For Working Voltages From 3.3 KV Up To And Including 33 KV As Per IS 7098 (Part 2) (550 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Types of cable	Three-core armoured, screened
	Voltage Grade	Earthed systems: 6.35/11 kV
	Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same)	Yes

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest	Aluminium
	Outer sheath (Type ST2)	PVC
	"Nominal Cross Sectional Area of Conductor	120
CONSTRUCTIONAL	Armouring	Galvanized formed wires armoured
	Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest	Wooden drum

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	550	45

Xlpe Cables, Category C2 - FR - LSH, For Working Voltages From 3.3 KV Up To And Including 33 KV As Per IS 7098 (Part 2) (500 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Types of cable	Three-core armoured, screened
	Voltage Grade	Earthed systems: 6.35/11 kV

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest	Aluminium
	Outer sheath (Type ST2)	PVC
	"Nominal Cross Sectional Area of Conductor	185
CONSTRUCTIONAL	Armouring	Galvanized formed wires armoured
	Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest	Wooden drum

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	500	45

Xlpe Cables, Category C2 - FR - LSH, For Working Voltages From 3.3 KV Up To And Including 33 KV As Per IS 7098 (Part 2) (450 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Types of cable	Three-core armoured, screened
	Voltage Grade	Earthed systems: 19/33 kV
	Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest	Aluminium
	Outer sheath (Type ST2)	PVC
	"Nominal Cross Sectional Area of Conductor	300
CONSTRUCTIONAL	Armouring	Galvanized formed wires armoured
	Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest	Wooden drum

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	450	45

Xlpe Cables, Category C2 - FR - LSH, For Working Voltages From 3.3 KV Up To And Including 33 KV As Per IS 7098 (Part 2) (452 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Types of cable	Three-core armoured, screened
	Voltage Grade	Earthed systems: 19/33 kV
	Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest	Aluminium
	Outer sheath (Type ST2)	PVC
	"Nominal Cross Sectional Area of Conductor	400
CONSTRUCTIONAL	Armouring	Galvanized formed wires armoured
	Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest	Wooden drum

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	452	45

PVC Copper Cable Single Core And Multi Core Circular Sheathed Cable With Rigid Conductor (V2) As Per IS 694 (532 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable (As per Cl 1.1 of IS 694)	FR
	Conductor material (shall conforming to IS:8130)	Annealed Bare copper
	Form of conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	6.0
	Type of Insulation (shall conforming to IS:5831)	Type C (HR)
	No of core	4 Core
	Sheath type	Type ST2 (HR)
CERTIFICATIONS	Availability of Test Certificates from any OEM, Govt Lab, NABL Accredited Lab	Yes
	Agree to provide all relevant documents including Test Report/supporting document / reports / BIS certificate etc to the buyer at the time of bidding or on demand	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	532	45

PVC Copper Cable Single Core And Multi Core Circular Sheathed Cable With Rigid Conductor (V2) As Per IS 694 (532 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable (As per Cl 1.1 of IS 694)	01
	Conductor material (shall conforming to IS:8130)	Annealed Tinned Copper
	Form of conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	10.0
	Type of Insulation (shall conforming to IS:5831)	Type A
	No of core	3 Core
	Sheath type	Type ST2 (HR)
CERTIFICATIONS	Availability of Test Certificates from any OEM, Govt Lab, NABL Accredited Lab	Yes
	Agree to provide all relevant documents including Test Report/supporting document / reports / BIS certificate etc to the buyer at the time of bidding or on demand	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	532	45

PVC Copper Cable Single Core And Multi Core Circular Sheathed Cable With Rigid Conductor (V2) As Per IS 694 (532 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable (As per Cl 1.1 of IS 694)	01
	Conductor material (shall conforming to IS:8130)	Annealed Bare copper
	Form of conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	6.0
	Type of Insulation (shall conforming to IS:5831)	Type A
	No of core	3 Core
	Sheath type	Type ST1
CERTIFICATIONS	Availability of Test Certificates from any OEM, Govt Lab, NABL Accredited Lab	No
	Agree to provide all relevant documents including Test Report/supporting document / reports / BIS certificate etc to the buyer at the time of bidding or on demand	No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	532	45

PVC Copper Cable Single Core And Multi Core Circular Sheathed Cable With Rigid Conductor (V2) As Per IS 694 (1563 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable (As per Cl 1.1 of IS 694)	01
	Conductor material (shall conforming to IS:8130)	Annealed Bare copper
	Form of conductor	Stranded (Class 2)
	Nominal Cross Sectional Area of Conductor (in Sq mm)	2.5
	Type of Insulation (shall conforming to IS:5831)	Type A
	No of core	3 Core
	Sheath type	Type ST1
CERTIFICATIONS	Availability of Test Certificates from any OEM, Govt Lab, NABL Accredited Lab	No
	Agree to provide all relevant documents including Test Report/supporting document / reports / BIS certificate etc to the buyer at the time of bidding or on demand	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	1563	45

LED FLAME PROOF HIGHT FITTING 200W (100 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

क्रेता विशिष्टि दस्तावेज़ /Buyer Specification Document	Download
---	--------------------------

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	100	45

SOLAR ALL IN ONE 60W 125LPW 100WP 42AH (20 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

क्रेता विशिष्टि दस्तावेज़ /Buyer Specification Document	Download
--	--------------------------

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	20	45

LED FLAME PROOF FOR TWIN T8 TUBE 20WATT (72 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

क्रेता विशिष्टि दस्तावेज़ /Buyer Specification Document	Download
--	--------------------------

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Visakhapatnam	72	45

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/**Buyer Added Bid Specific Terms and Conditions**

1. **Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/**Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or

bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---