

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	05-02-2026 16:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	05-02-2026 16:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	30 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Military Affairs
संगठन का नाम/Organisation Name	Indian Army
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	530
वस्तु श्रेणी /Item Category	PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694 (Q2) , MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , Switch Fuse Unit (Q3) , Non - Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3) , Piano Type Non Modular Electrical Switch Socket Combination as per IS 3854 and IS 1293 (Q3) , Piano Type Non Modular Domestic Fan Regulator as per IS 11037 (Q3) , Piano Type Non Modular Domestic Electrical sockets - IS 1293 (Q3) , Electric Bells and Accessories as per IS 2268 (Q3) , Metal Alloy Casting Water Tap with Aerator (V2) (Q3) , LED Bulkhead Light (Q3) , LED Garden Light (V2) (Q2) , Curtain Pipe, Sider and mounting bracket (Q4)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No

बिड विवरण/Bid Details	
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन /Past Performance	80 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Curtain Pipe, Sider and mounting bracket
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
--------------------------	----

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM_No.1 4 2021_PPD_dated_18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

3. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having

highest bid value should meet this criterion.

4. Short Duration Bid has been published by the Buyer with the approval of the Competent authority due to Emergency procurement of critical products/services.

5. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (90 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	6
CONSTRUCTION	Type of Insulation	Type C (HR)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	90	30

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (90 meter)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	FR-LSH
	Nominal Area of Conductor (in Sq. mm)	10
CONSTRUCTION	Type of Insulation	Type D

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	90	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (19 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	6
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	19	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (12 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	10
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	12	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (14 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	16
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	14	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (9 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	20
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	9	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (8 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	8	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (3 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	10
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	3	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (3 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 1 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	3	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (16 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	32, 40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	16	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (12 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	12	30

MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) (6 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	4 P with 3 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	6	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	100A
	No of poles/Protected poles(PP)	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	63A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	Breaking current (in KA)	25 KA
	Rated Voltage	240 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	63A
	No of poles/Protected poles(PP)	4 Pole

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	1	30

Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	ISI marked	NO
	Rated Current (in Ampere)	125A
	No of poles/Protected poles(PP)	4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA
	Rated Voltage	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	1	30

Switch Fuse Unit (2 pieces)**तकनीकी विशिष्टियाँ /Technical Specifications**

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATINGS	Rated operational Voltage (in Volt)	415
	Rated frequency (in Hz)	50
	Number of Pole	4 Pole
	Current rating (in Ampere)	100
	Rated Insulation voltage (in Volt)	660
	Rated impulse withstand voltage (in KV)	3
	Rated short circuit breking capacity, Minimum (in KA, r.m.s.)	3
GENERIC	Whether product ISI Marked (Select 2 for ISI Marked product, Select 1 for Non ISI Marked product)	2, 1 Or higher
	Switch Fue Unit contains	Operating handle
	Utilisation category	AC-22A
	Warranty (in Years)	1.0 - 5.0 Or higher
CONSTRUCTION	Material of enclosure	CRCA Sheet, 2 mm thick
	Degree of protection	IP54
	Mechanical Endurance, Minimum (in No.of cycles)	10000
	Fixing accessories for mounting of encllosures	Yes
FUSE UNIT	Type of fuse	Rewirable Porcelain Fuse units

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	2	30

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (4 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	6A
	Nature of Switch	bell push switch
	Rated voltage	240.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	surface type
Construction	Current carrying material	Brass
	Color of switch body	Off-white
Certification & standards	Warranty	1.0 (year)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	4	30

Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 (42 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	16A
	Nature of Switch	1 way switch

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Rated voltage	240.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	surface type
Construction	Current carrying material	Brass
	Color of switch body	Others
Certification & standards	Warranty	1.0 (year)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N O.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	42	30

Piano Type Non Modular Electrical Switch Socket Combination As Per IS 3854 And IS 1293 (21 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	16A
	Rated voltage	250.0 (Volt)
	Combination with Junction Box	Without Box
Construction	According to type of terminal	Screw type terminal
	Current carrying material	Copper
	Color of switch body	White
Certification & standards	Warranty	2.0 (year)

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	21	30

Piano Type Non Modular Domestic Fan Regulator As Per IS 11037 (6 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	BIS Marking	Yes
	Rated voltage	230.0 (Volt)
	Type of Regulator	socket size
	No of steps	5
Construction	Color of regulator body	White
Certification & standards	Test report to be submitted to the Buyer on Demand	Yes

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	6	30

Piano Type Non Modular Domestic Electrical Sockets - IS 1293 (11 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Current	16.0 (Ampère)
Generic	Socket type based on existence of shutter	Without Shutter
	Current Carrying Material	Brass
	According to type of Terminal	Screw Type Terminal
	Number of Modules	2
	Number of Poles	3
	Number of Pins	6
	Warranty	1.0 (year)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	11	30

Electric Bells And Accessories As Per IS 2268 (4 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Product ISI marked	NO - But conforming to IS:2268
	Type of bell	Ding Dong type

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	4	30

Metal Alloy Casting Water Tap With Aerator (V2) (28 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Tap Mounting Type	Pillar tap
Material	Material	Brass
Description	Type of Faucet	Multi Turn
	Aerator Material	Metal
Dimension	Nominal Thread Size of Tap (mm)	15

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	28	30

LED Bulkhead Light (21 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Material	Plastic
	Protection	IP65
	Driver included	Yes
Performance Parameters	Life Time	50000.0 (hour)
	Protection class IEC	Safety class I (I)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Luminous flux (system flux)	1000.0 (lumen)
Dimensions and Size	Depth	100.0 (millimeter)
	Length	175.0 (millimeter)
	Width	80.0 (millimeter)
Warranty	Warranty	2 Or higher (year)

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	21	30

LED Garden Light (V2) (2 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Type of Garden Light	Bollard type with Pole and LED lantern/luminaire, Architectural design with pole and LED lantern/luminaire, LED post top lantern/luminaire with pole
	Material of Garden Lighting pole including lighting system (lantern/luminaire) (Note: Wherever GI, MS, CI materials used, materials shall be ISI Marked)	Aluminium casting, Galvanised Iron, Mild steel, Cast iron, LED post top with out pole. Hence not applicable
	Pole height including lantern/luminaire (in m)	0.5, 1, 1.5, 3, 4, 5, 6, 7, 8, without pole
	No.of lantern/luminaire with each pole (in m)	1, 2, 3, 4, 5, LED post top with out pole. Hence not applicable
LIGHT SOURCE	Type of light source - BEE star rating of LED Bulb	SMD LED Chip
	LED Rating in each lantern/luminaire/lighting system (in Watts)	25.0

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	LED Lamp/System efficacy in each lantern / luminaire (in lumen / watt)	? 105 and < 120
	In case of LED bulb - Cap designation of each lamp and holder in each lantern / luminaire	Not applicable (for SMP LED Chip)
PROTECTION	Automatic Lower / Higher Cut off voltage	Yes. Lower cut off 120 V, Higher cut off 300 V
	Protection against surges and transients - External	> / = 10 KV, No Or higher
THERMAL MANAGEMENT	Minimum Operating Temperature (in deg. C)	-10
	Maximum Operating Temperature (in deg. C)	50
LANTERN/LUMINAIRE - CONSTRUCTION	Impact resistance on diffuser material (in IK)	7
	Protection of the entire housing (in IP) Protection of the entire housing as per IS:10322 (Part 1):1982 latest	65
	Length of ISI marked three core connecting wire (Provided along with each lantern/luminiare) - (in m)	1
CERTIFICATIONS	Warranty for free replacement of lighting systems including lightsource (in years)	2
ADVANCE SAMPLE	Agreed to provide Advance Sample(s) for buyer's approval before commencement of supply. (hint: Applicable in case of orders placed against bid and not applicable in case of Direct Buying)	No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	2	30

Curtain Pipe, Sider And Mounting Bracket (100 meter)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	ITEM	Hanging Bracket
OTHER REQUIREMENTS	Sider(one pair per pipe)	With
DIMENSON	Outside Diameter of curtain pipe (in mm)	25mm
	Length of curtain pipe(In Meter)	5
	Minimum Wall thickness of pipe (In MM)	4, 5 Or higher
	Minimum thickness of Curtain pipe hanging bracket (in mm)	3 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	100	30

Metal Alloy Casting Water Tap With Aerator (V2) (3 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ITEM	Tap Mounting Type	Mixers tap
Material	Material	Brass

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Description	Type of Faucet	Half Turn
	Aerator Material	Metal
Dimension	Nominal Thread Size of Tap (mm)	15

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bathinda	3	30

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

3. Certificates

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

4. Certificates

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

5. Certificates

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

6. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

1. Bidder must upload OEM authorization certificate with specific bid No, failing which bidder is disqualified from the bidding.
2. Bidder must offer their rates along with **Make and Model/CAT No.**, failing which bid will be disqualified.
3. Bidder must upload current price list of each make against which they are offering the rates.
4. Bidder must quote their rates for the following makes: -
 - (a) **PVC Cables(copper)** :-Plaza/KEI/Havells / Any make approved by HQ CE WC and E-in-C`s Br.
 - (b) **Flush type Piano Type non modular Electrical switches/sockets , Electric bell, fan regulator** - Anchor/Kinjal/Adhunik/Benlo/ Any make approved by HQ CE WC and E-in-C`s Br.
 - (c) **Molded Case Circuit Breakers, MCB and switch fuse unit**- Indoasian/Havells/HPL / Any make approved by HQ CE WC and E-in-C`s Br.
 - (d) **Brass (bib cock, mixer tap, wall mount & float valve)**- Prayag/Shakti/Prima/ Any make approved by HQ CE WC and E-in-C`s Br.
 - (e) **LED Bulk head light** -Orient Elect/HPL/Crompton/Bajaj/ Any make approved by HQ CE WC and E-in-C`s Br.
5. The bid will be rejected if any of the document / certificate as requested in GeM bid has not been uploaded by the bidder.

7. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.

5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms

of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---