

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	28-02-2026 12:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	28-02-2026 12:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Military Affairs
संगठन का नाम/Organisation Name	Indian Army
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	21004
वस्तु श्रेणी /Item Category	LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3) (Q3) , Terminal Ends for Aluminium Conductors of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (Q3) , PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694 (Q2) , PVC Flat Cable, Aluminium Conductor with PVC Insulation and Sheath as per IS 694 (Q3) , PVC Flat Cable, Copper Conductor with PVC Insulation and Sheath as per IS 694 (Q3) , Cord flexible 3 core copper 0.75 sqmm , Cord flexible 3 core copper 1 sqmm , PVC Flexible Twin Twisted Cable 23.0076 , PVC Flexible Twin Twisted Cable 40.0076 , Cooper Fuse wire 10 Amp , Cooper Fuse wire 15 Amp , Cooper Fuse wire 20 Amp , Cooper Fuse wire 30 Amp , Cooper Fuse wire 40 Amp , Cooper Fuse wire 60 Amp , Cooper Fuse wire 100 Amp , DO Fuse Element 10 Amp , DO Fuse Element 20 Amp , DO Fuse Element 30 Amp
GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS	Cable copper T C 2.5 sqmm , Cord flexible 3 core copper 0.75 sqmm, Cord flexible 3 core copper 1 sqmm, PVC Flexible Twin Twisted Cable 23.0076, PVC Flexible Twin Twisted Cable 40.0076 , Cooper Fuse wire 10 Amp, Cooper Fuse wire 15 Amp, Cooper Fuse wire 20 Amp, Cooper Fuse wire 30 Amp, Cooper Fuse wire 40 Amp, Cooper Fuse wire 100 Amp, DO Fuse Element 20 Amp, DO Fuse Element 30 Amp, Lugs Almn 16 Sqmm, Lugs Almn 25 Sqmm, Lugs Almn 35 Sqmm, Lugs Almn 50 Sqmm, Lugs Almn 70 Sqmm, Lugs Almn 95 Sqmm, Lugs Almn 120 Sqmm, Lugs Almn 150 Sqmm, Lugs Almn 185 Sqmm, Lugs Almn 240 Sqmm, Lugs Almn 300 Sqmm, Lugs Almn 400 Sqmm, Lugs copper 70 sqmm, Lugs copper 120 sqmm, Lugs copper 150 sqmm
	Searched String: Cable copper T C 2.5 sqmm PVC Copper Cable (Heavy Duty) - Type A PVC Compound,

विड विवरण / Bid Details	Category C 2 - FR - LSH as per IS 1554 (Part 1), XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1), PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category 01 as per IS 1554 (Part 1), PVC Copper Cable Single and Multi Core Circular Sheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category C1 - FR as per IS 1554 (Part 1), PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cable with Rigid Conductor (V2) as per IS 694, PVC Insulated Cables for Submersible Pumps - as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cord with Flexible Conductor (V2) as per IS 694
	<p>Searched String: Cord flexible 3 core copper 0.75 sqmm</p> <p>PVC Copper Cable Single Core and Multi Core Circular Sheathed Cord with Flexible Conductor (V2) as per IS 694, PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Elastomer Insulated, Unkinkable Flexible Cords (Workshop Type) - IS 9968 (Part 1), PVC Copper Cable Single and Multi Core Circular Sheathed Cord with Flexible Conductor as per IS 694, Elastomer Insulated, Textile Braided Cables - IS 9968 (Part 1), PVC Copper Cable Single and Multi Core Circular Sheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cable with Rigid Conductor (V2) as per IS 694, Multicore Cable as per IS 694, PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category C1 - FR as per IS 1554 (Part 1)</p> <p>Searched String: Cord flexible 3 core copper 1 sqmm</p> <p>Elastomer Insulated, Unkinkable Flexible Cords (Workshop Type) - IS 9968 (Part 1), PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Elastomer Insulated, Textile Braided Cables - IS 9968 (Part 1), PVC Copper Cable Single Core and Multi Core Circular Sheathed Cord with Flexible Conductor (V2) as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cable with Rigid Conductor (V2) as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cord with Flexible Conductor as per IS 694, PVC Copper Cable 1 Core and Multi Core Circular Sheathed Cable with Rigid Conductor as per IS 694, PVC Copper Cable Multi Core Circular Sheathed Cables with Flexible Conductor as per IS 694, PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694</p> <p>Searched String: PVC Flexible Twin Twisted Cable 23.0076</p> <p>PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cord with Flexible Conductor (V2) as per IS 694, PVC Copper</p>

विड विवरण / Bid Details

Cable Multi Core Circular Sheathed Cables with Flexible Conductor as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cord with Flexible Conductor as per IS 694

Searched String: PVC Flexible Twin Twisted Cable 40.0076

PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cable with Flexible Conductor as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cord with Flexible Conductor (V2) as per IS 694, PVC Copper Cable Multi Core Circular Sheathed Cables with Flexible Conductor as per IS 694, PVC Copper Cable Single and Multi Core Circular Sheathed Cord with Flexible Conductor as per IS 694, PVC Copper Cable Single Core and Multi Core Circular Sheathed Cable with Rigid Conductor (V2) as per IS 694, PVC Single Core and Multi Core Circular Sheathed Aluminium Cable with Rigid Conductor (V2) as per IS 694, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category 01 as per IS 1554 (Part 1)

Searched String: Cooper Fuse wire 10 Amp

Fuse Wire as per IS 9926, Electrical Extension Box (V4), Power Generator - DG Set (up to 900 KVA), Mechanically Woven, Double - Twisted, Hexagonal Wire Mesh Gabions, Revet Mattresses and Rock Fall Netting as per IS 16014, Light Weight Running Shoes (V2) (MHA), XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1), High Strength Deformed Steel Bars and Wires for Concrete Reinforcement (V2) ISI marked to IS 1786, Self Fusing Silicon Rubber Tape, Circuit Breakers with Integral Overcurrent Protection (RCBO) as per IS 12640 (Part 2) IEC 61009 - 1, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category 01 as per IS 1554 (Part 1)

Searched String: Cooper Fuse wire 15 Amp

Fuse Wire as per IS 9926, Electrical Extension Box (V4), GTAW wire ER 347 - BHEL, Power Generator - DG Set (up to 900 KVA), Wire Mesh Fabric or Cloth (V2) as per IS 1568, Polyester Enamelled Round Copper Wire, Class 155 (V2) as per IS 13730 (Part 3), Taflon Tape as per IS 14635, Polyester Enamelled Round Copper Wire, Class 155 as per IS 13730 (Part 3), Galvanized Steel Chain Link Fence Fabric (V2) conforming to IS 2721, Mechanically Woven, Double - Twisted, Hexagonal Wire Mesh Gabions, Revet Mattresses and Rock Fall Netting as per IS 16014

Searched String: Cooper Fuse wire 20 Amp

Fuse Wire as per IS 9926, Carriers and bases in rewirable type electric fuses conforming to IS 2086, Power Generator - DG Set (up to 900 KVA), Ferro Silica Calcium Cored Wire as per IS 2022, Tapered Bearings as per IS 12102, Audio Amplifier (V3) (under BIS Scheme - II), Freight Containers - High Security Cable Seal as per IS 17381:2021, High Strength Deformed Steel Bars and Wires for Concrete Reinforcement (V2) ISI marked to IS 1786, Single switch IGBT Module, Glass Fuse

Searched String: Cooper Fuse wire 30 Amp

बिड विवरण / Bid Details	Fuse Wire as per IS 9926, Power Generator - DG Set (up to 900 KVA), Tapered Bearings as per IS 12102, Spherical Roller Bearing as per IS 6455, Single switch IGBT Module, Cylindrical Fuses, High Pressure Fire Fighting Hose - IS 14933
<p>GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS</p>	<p>Searched String: Cooper Fuse wire 40 Amp</p> <p>Fuse Wire as per IS 9926, Spherical Roller Bearing as per IS 6455, WELDING ELECTRODE - Solid wire for TIG welding (BEML) -as per C4012 BEML Welding Electrode, Power Generator - DG Set (up to 900 KVA), WELDING ELECTRODE - Solid wire for submerged arc welding (BEML) -as per C4011 BEML Welding Electrode, Welding Electrode - Copper Coated Solid Wire for Co2 Gas Shielded Arc Welding (BEML) as per C4002 BEML Welding Electrode, Tapered Bearings as per IS 12102, Galvanized Steel Chain Link Fence Fabric (V2) conforming to IS 2721, Control Cable, Circuit Breakers with Integral Overcurrent Protection (RCBO) as per IS 12640 (Part 2) IEC 61009 - 1</p> <p>Searched String: Cooper Fuse wire 100 Amp</p> <p>Fuse Wire as per IS 9926, Spherical Roller Bearing as per IS 6455, Power Generator - DG Set (up to 900 KVA), Mechanically Woven, Double - Twisted, Hexagonal Wire Mesh Gabions, Revet Mattresses and Rock Fall Netting as per IS 16014, Tapered Bearings as per IS 12102, Automatic Fully Mechanised Organic Waste Machine for Compost, Multicore Cable as per IS 694, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category 01 as per IS 1554 (Part 1), Circuit Breakers with Integral Overcurrent Protection (RCBO) as per IS 12640 (Part 2) IEC 61009 - 1</p> <p>Searched String: DO Fuse Element 20 Amp</p> <p>Carriers and bases in rewirable type electric fuses conforming to IS 2086, Tapered Bearings as per IS 12102, Jacket (UP Police), Audio Amplifier (V3) (under BIS Scheme - II), Glass Fuse, Door Handles (V2) ISI marked to IS 208, Single switch IGBT Module, Door Handles as per IS 208, Circuit Breakers with Integral Overcurrent Protection (RCBO) as per IS 12640 (Part 2) IEC 61009 - 1, Document Management Software (V2)</p> <p>Searched String: DO Fuse Element 30 Amp</p> <p>Hopper Heating Element as per IS 302, IS 4159, Tapered Bearings as per IS 12102, Shaft Insulator Heater-IS:302, IS:4159, Laboratory Refrigerator (V2), Spherical Roller Bearing as per IS 6455, Heated Display Case - Hot Case (V2), Single switch IGBT Module, Cylindrical Fuses, Switching Power Supply for Wireless Application</p> <p>Searched String: Lugs Almn 16 Sqmm</p> <p>PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1)</p> <p>Searched String: Lugs Almn 25 Sqmm</p> <p>PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, PVC Insulated</p>

विड विवरण / Bid Details

Cables, Unsheathed with Rigid Conductor (V2) as per IS 694, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category C1 - FR as per IS 1554 (Part 1)

Searched String: Lugs Almn 35 Sqmm

PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), Electrical connection Lugs or thimbles, PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694

Searched String: Lugs Almn 50 Sqmm

PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), Compression cable lugs

Searched String: Lugs Almn 70 Sqmm

PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, Compression cable lugs, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1)

Searched String: Lugs Almn 95 Sqmm

PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, Compression cable lugs, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1)

Searched String: Lugs Almn 120 Sqmm

Compression cable lugs, Electrical connection Lugs or thimbles, PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1)

Searched String: Lugs Almn 150 Sqmm

Electrical connection Lugs or thimbles, Compression cable lugs, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694

Searched String: Lugs Almn 185 Sqmm

Compression cable lugs, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694

Searched String: Lugs Almn 240 Sqmm

Compression cable lugs, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as

बिड विवरण / Bid Details	per IS 1554 (Part 1)
	<p>Searched String: Lugs Almn 300 Sqmm</p> <p>PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), Compression cable lugs, PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694</p> <p>Searched String: Lugs Almn 400 Sqmm</p> <p>PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), Compression cable lugs</p> <p>Searched String: Lugs copper 70 sqmm</p> <p>PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, PVC Insulated Cables, Unsheathed with Rigid Conductor (V2) as per IS 694, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category C1 - FR as per IS 1554 (Part 1), PVC Copper Cable Single and Multi Core Circular Sheathed Cable with Flexible Conductor as per IS 694, Compression cable lugs, PVC Aluminium Cable (Heavy Duty), Working Voltages up to and Including 1100 Volts as per IS 1554 (Part 1), PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694, XLPE Cable for Working Voltages up to and Including 1.1 KV as per IS 7098 (Part 1)</p> <p>Searched String: Lugs copper 120 sqmm</p> <p>PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, PVC Insulated Cables, Unsheathed with Rigid Conductor (V2) as per IS 694, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category C1 - FR as per IS 1554 (Part 1), Compression cable lugs</p> <p>Searched String: Lugs copper 150 sqmm</p> <p>Copper Oxychloride Water Dispersible Powder Concentrate (V2) Conforming to IS 1507, PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Electrical connection Lugs or thimbles, PVC Insulated Cables, Unsheathed with Rigid Conductor (V2) as per IS 694, PVC Copper Cable (Heavy Duty), Type C PVC Compound, Category C1 - FR as per IS 1554 (Part 1), Compression cable lugs</p>
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	<ul style="list-style-type: none"> • PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694
बीओक्यू शीर्षक / BOQ Title	Street light
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)	26 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)	51 Lakh (s)

बिड विवरण/Bid Details	
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/ Years of Past Experience Required for same/similar service	1 Year (s)
वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover	Yes Partial Experience - 1 year (s) Turn over value - 1 (in lakhs)
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover	Yes Partial Experience - 1 year (s) Turn over value - 1 (in lakhs)
विक्रेता से मांगे गए दस्तावेज़/ Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/ Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	2
विगत प्रदर्शन / Past Performance	30 %
बिड से रिवर्स नीलामी सक्रिय किया/ Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/ RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/ Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/ Primary product category	Cord flexible 3 core copper 0.75 sqmm
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय / Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No

बिड विवरण/Bid Details

मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	103000

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	6

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

CWE Mathura

Commander Works Engineer Mathura, Department of Military Affairs, Indian Army, Ministry of Defence
(Ashok Kumar)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में है / Purchase Preference to MII sellers available upto price within $L1+X\%$	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50

सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)
---	---

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within $L1+X\%$	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.
5. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
7. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid

document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

8. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

9. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

10. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

11. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 30% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

12. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (15 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	18
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	8	15
2	*****	*****Mathura	7	15

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (44 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	36
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	3, 4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	10	15

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
2	*****	*****Mathura	34	15

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (34 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	40
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	10	15
2	*****	*****Mathura	24	15

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (9 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	48
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	2, 3, 4, 5 Or higher

परिषदी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषदी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	9	15

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (36 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	60
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	15	15
2	*****	*****Mathura	6	15
3	*****	*****Bharatpur	15	15

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (53 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	70
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	40 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	35	15
2	*****	*****Mathura	8	15
3	*****	*****Bharatpur	10	15

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (46 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	90
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	2 Or higher
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	24	15
2	*****	*****Mathura	4	15
3	*****	*****Bharatpur	18	15

LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) (30 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	LED Rating (in Watts)/ System Wattage/ Rated Power	120
	LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)	100, 120, 140 Or higher
ELECTRICAL CHARACTERISTIC	Input operating voltage range and frequency	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	Number of electronic control gear in the luminaire (power supplies)	1, 2 Or higher

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LUMINAIRE	Provision of luminaire connecting wire along with the supply of material	50 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	30	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (16)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-16/8.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-16/8.4

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	16	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (59 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-25/6.4
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-25/8.4

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	23	15
2	*****	*****Bharatpur	36	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (54 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-35/10.2

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-35/10.5

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	18	15
2	*****	*****Bharatpur	36	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (52 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-50/6.4
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX- 50/10.5

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	24	15
2	*****	*****Bharatpur	28	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (58 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-70/12.7
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-70/13.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	14	15
2	*****	*****Mathura	8	15
3	*****	*****Bharatpur	36	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (81 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-95/12.7
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX- 95/13.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	37	15
2	*****	*****Mathura	8	15
3	*****	*****Bharatpur	36	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (49 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-120/10.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX- 120/13.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	8	15
2	*****	*****Mathura	7	15
3	*****	*****Bharatpur	34	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (42 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-150/10.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-150/13.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	12	15
2	*****	*****Bharatpur	30	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (50 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-185/10.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-185/17.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	12	15
2	*****	*****Mathura	8	15

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
3	*****	*****Bharatpur	30	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (36)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA- 240/12.7
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX- 240/17.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	36	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (43)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-300/20.3
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX- 300/17.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	5	15
2	*****	*****Mathura	8	15
3	*****	*****Bharatpur	30	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (10)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA- 400/16.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX- 400/17.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	2	15
2	*****	*****Mathura	8	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (20 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-70/8.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-70/13.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	20	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (20 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-120/10.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX- 120/13.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	20	15

Terminal Ends For Aluminium Conductors Of Insulated Cables (Compression Cable Lugs) Conforming To IS 8309 (20 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Designation/Stud Hole (in mm)	CAA-150/10.2
	Designation/Stud Hole (in mm) - For XLPE Cables	CAAX-150/13.0

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	20	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (500 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	01
	Nominal Area of Conductor (in Sq. mm)	0.75
CONSTRUCTION	Type of Insulation	Type C (HR)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	500	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1000 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	02
	Nominal Area of Conductor (in Sq. mm)	1
CONSTRUCTION	Type of Insulation	Type C (HR)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	1000	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (3100 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	02
	Nominal Area of Conductor (in Sq. mm)	1.5
CONSTRUCTION	Type of Insulation	Type C (HR)

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	900	25
2	*****	*****Mathura	1200	25
3	*****	*****Bharatpur	1000	25

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (2600 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	01
	Nominal Area of Conductor (in Sq. mm)	2.5
CONSTRUCTION	Type of Insulation	Type C (HR)

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1000	15
2	*****	*****Mathura	800	15
3	*****	*****Bharatpur	800	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	02
	Nominal Area of Conductor (in Sq. mm)	4
CONSTRUCTION	Type of Insulation	Type C (HR)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	200	15
2	*****	*****Mathura	500	15
3	*****	*****Bharatpur	500	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (1200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	02
	Nominal Area of Conductor (in Sq. mm)	6
CONSTRUCTION	Type of Insulation	Type C (HR)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	200	15
2	*****	*****Mathura	600	15
3	*****	*****Bharatpur	400	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (400 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	02
	Nominal Area of Conductor (in Sq. mm)	10
CONSTRUCTION	Type of Insulation	Type C (HR)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	200	15
2	*****	*****Mathura	200	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (100 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	01

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Nominal Area of Conductor (in Sq. mm)	50
CONSTRUCTION	Type of Insulation	Type D

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	100	15

PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (1400 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type A
	No. of core	2
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 2 (HR)
	Nominal Area of Conductor (in Sq.mm)	2.5
	Optional tape between the cores and outer sheath	Yes

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	300	15
2	*****	*****Mathura	700	15
3	*****	*****Bharatpur	400	15

PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (1400 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C (HR)
	No. of core	2
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 1
	Nominal Area of Conductor (in Sq.mm)	4.0
	Optional tape between the cores and outer sheath	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	400	15
2	*****	*****Mathura	600	15
3	*****	*****Bharatpur	400	15

PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (1200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C (HR)
	No. of core	2
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 1
	Nominal Area of Conductor (in Sq.mm)	6.0
	Optional tape between the cores and outer sheath	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	200	15
2	*****	*****Mathura	600	15
3	*****	*****Bharatpur	400	15

PVC Flat Cable, Aluminium Conductor With PVC Insulation And Sheath As Per IS 694 (1400 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C (HR)
	No. of core	2
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 2 (HR)
	Nominal Area of Conductor (in Sq.mm)	10.0
	Optional tape between the cores and outer sheath	No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	400	15
2	*****	*****Mathura	700	15
3	*****	*****Bharatpur	300	15

PVC Flat Cable, Copper Conductor With PVC Insulation And Sheath As Per IS 694 (200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type A
	No. of core	3

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Conductor material (Complying with IS:8130:1984 latest)	Tinned Copper
	Nominal Area of Conductor (in Sq.mm)	6.0
	Optional tape between the cores and outer sheath	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	100	15
2	*****	*****Bharatpur	100	15

PVC Flat Cable, Copper Conductor With PVC Insulation And Sheath As Per IS 694 (300 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type A
	No. of core	3
	Conductor material (Complying with IS:8130:1984 latest)	Tinned Copper
	Nominal Area of Conductor (in Sq.mm)	10.0
	Optional tape between the cores and outer sheath	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	200	15
2	*****	*****Bharatpur	100	15

PVC Flat Cable, Copper Conductor With PVC Insulation And Sheath As Per IS 694 (200 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Category of Cable	01
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type A
	No. of core	3
	Conductor material (Complying with IS:8130:1984 latest)	Plain copper
	Nominal Area of Conductor (in Sq.mm)	16.0
	Optional tape between the cores and outer sheath	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	200	15

PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 (100 meter)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local

Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)**तकनीकी विशिष्टियाँ /Technical Specifications**

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Cable category	FR
	Nominal Area of Conductor (in Sq. mm)	70
CONSTRUCTION	Type of Insulation	Type C (HR)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	100	15

Cord Flexible 3 Core Copper 0.75 Sqmm

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	100	15

Cord Flexible 3 Core Copper 1 Sqmm

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	100	15

PVC Flexible Twin Twisted Cable 23.0076

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	800	15

PVC Flexible Twin Twisted Cable 40.0076

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	2800	15

Cooper Fuse Wire 10 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

Cooper Fuse Wire 10 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	5	15

Cooper Fuse Wire 15 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	4	15

Cooper Fuse Wire 20 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

Cooper Fuse Wire 20 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	3	15

Cooper Fuse Wire 30 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

Cooper Fuse Wire 30 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Bharatpur	5	15

Cooper Fuse Wire 40 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
-------------------------------	---------------------------

BOQ Detail Document[View File](#)

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

Cooper Fuse Wire 60 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

Cooper Fuse Wire 100 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

DO Fuse Element 10 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	2	15

DO Fuse Element 20 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषीती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषीती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

DO Fuse Element 30 Amp

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषीती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषीती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****Mathura	1	15

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be (Increased quantity ÷ Original quantity) × Original delivery period (in days), subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Generic**

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

3. **Generic**

Bidders shall quote only those products (Part of Service delivery) in the bid which are not obsolete in the market and has at least 1 years residual market life i.e. the offered product shall not be declared end-of-life by the OEM before this period.

4. **Generic**

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- a. Copy of PAN Card.
- b. Copy of GSTIN.
- c. Copy of Cancelled Cheque.
- d. Copy of EFT Mandate duly certified by Bank.

5. **Generic**

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for 3 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

6. **Generic**

Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

7. **Generic**

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

8. **Generic**

1. The Seller shall not assign the Contract in whole or part without obtaining the prior written consent of buyer.
2. The Seller shall not sub-contract the Contract in whole or part to any entity without obtaining the prior written consent of buyer.
3. The Seller shall, notwithstanding the consent and assignment/sub-contract, remain jointly and severally liable and responsible to buyer together with the assignee/ sub-contractor, for and in respect of the due performance of the Contract and the Sellers obligations there under.

9. **Generic**

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.

- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

10. **Inspection**

Nominated Inspection Agency: On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:
Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC):

BOO

Post Receipt Inspection at consignee site before acceptance of stores:
BOO

11. **Sample Clause**

After award of contract - Successful Bidder shall have to get advance sample approved from buyer before bulk manufacturing / starting bulk supplies. Successful Bidder shall submit

54

samples for Buyer's approval, within 7 days of award of contract. Buyer shall, as per contract specifications framework, either approve the advance sample or will provide complete list of modification required in the sample within 7 days of receipt of advance sample. Seller shall be required to ensure supply as per approved sample with modifications as communicated by Buyer. If there is delay from buyer side in approval of advance sample - the delivery period shall be refixed without LD for the period of delay in sample approval. In case, the sample is found to have major deviations / not conforming to the Contract specifications, the buyer at its discretion may call for fresh samples for approval before allowing bulk supplies or may terminate the contract after notifying the deviations to the seller.

Unless otherwise provided in the contract, all samples required for test shall be supplied by the contractor free of cost. Where under the contract, the contractor is required to submit an advance sample, any expenses incurred by the contractor on or in connection with the production of stores in bulk, before the sample has been approved unconditionally shall be borne by the Seller and he shall not claim any compensation in the event of such sample being found unacceptable by the Buyer / Consignee.

12. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

13. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

14. **Certificates**

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

15. **Certificates**

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

16. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

17. **Certificates**

To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the

date of bid opening (to be uploaded with bid):

Must required during tech evaluation

18. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

19. Turnover

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

20. Turnover

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

21. Forms of EMD and PBG

Successful Bidder can submit the Performance Security in the form of Fixed Deposit Receipt also (besides PBG which is allowed as per GeM GTC). FDR should be made out or pledged in the name of

HQ CWE Mattura

A/C (Name of the Seller). The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledgee. For release of Security Deposit, the FDR will be released in favour of bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Successful Bidder has to upload scanned copy of the FDR document in place of PBG and has to ensure delivery of hard copy of Original FDR to the Buyer within 15 days of award of contract.

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.

6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake

compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---