

**बिड दस्तावेज़ / Bid Document**

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	23-02-2026 16:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	23-02-2026 16:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	60 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Military Affairs
संगठन का नाम/Organisation Name	Indian Army
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	6089
वस्तु श्रेणी /Item Category	LED Luminaire (Recessed Luminaire) (V3) Conforming to IS 10322 (Part 5/Section 2) (Q3) , LED Batten (Q2) , Molded Case Circuit Breakers (MCCB) as per IS / IEC 60947 (Q3) , LED Luminaire for Road and Street Lights (V2) Conforming to IS 10322 (Part 5 / Section 3) (Q3) , PVC Insulated Unsheathed Cable with Flexible Conductor as per IS 694 (Q2) , Electrical Plugs (V2) ISI Marked to IS 1293 (Q2) , Piano Type Modular Domestic Electrical sockets - IS 1293 (Q3) , Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3) , Non - Modular Piano Type Domestic Electrical Switches as per IS 3854 (Q3) , Piano Type Non Modular Domestic Electrical sockets - IS 1293 (Q3)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	16 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)/OEM Average Turnover (Last 3 Years)	95 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover	Yes   Complete
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover	Yes   Complete

<b>बिड विवरण/Bid Details</b>	
<b>विक्रेता से मांगे गए दस्तावेज़/Document required from seller</b>	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
<b>क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?</b>	No
<b>बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension</b>	3
<b>दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended</b>	3
<b>ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count</b>	1
<b>विगत प्रदर्शन /Past Performance</b>	50 %
<b>बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled</b>	Yes
<b>रिवर्स नीलामी योग्यता नियम/RA Qualification Rule</b>	50% Lowest Priced Technically Qualified Bidders
<b>बिड का प्रकार/Type of Bid</b>	Two Packet Bid
<b>प्राथमिक उत्पाद श्रेणी/Primary product category</b>	LED Luminaire (Recessed Luminaire) (V3) Conforming to IS 10322 (Part 5/Section 2)
<b>तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation</b>	2 Days
<b>निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)</b>	No
<b>मूल्यांकन पद्धति/Evaluation Method</b>	Group wise evaluation
<b>मध्यस्थता खंड/Arbitration Clause</b>	No
<b>सुलह खंड/Mediation Clause</b>	No

#### ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
-----------------------------	---------------------

Group 1 ईएमडी राशि/EMD Amount (In INR)	30540
Group 2 ईएमडी राशि/EMD Amount (In INR)	33110

#### ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). The EMD Amount will be applicable for each schedule/group selected during Bid creation.

(c). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

#### लाभार्थी /Beneficiary :

CWE

CWE AF GURGAON, Department of Military Affairs, Indian Army, Ministry of Defence

(Cwe Af Gurgaon)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

#### एमआईआई के लिए आरक्षित / Reserved for Make In India products

एमआईआई के लिए आरक्षित / Reserved for Make In India products	Yes
---	-----

#### एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.

2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.

3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.

4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.

5. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

6. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

7. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

8. Bid reserved for Make In India products: : Procurement under this bid is reserved for purchase from Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. However, eligible micro and small enterprises will be allowed to participate. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

9. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM\\_No.1\\_4\\_2021\\_PPD\\_dated\\_18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

10. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

11. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

12. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

#### Evaluation Method ( Group Wise Evaluation Method )

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

Evaluation Schedule	Item/Category	Consignee/Reporting Officer	Consignee Address	Quantity
Group 1	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	1200
	Led Luminaire For Road And Street Lights (v2) Conforming To Is 10322 (part 5 / Section 3)	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	60
	Led Luminaire For Road And Street Lights (v2) Conforming To Is 10322 (part 5 / Section 3)	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	47
	Led Luminaire For Road And Street Lights (v2) Conforming To Is 10322 (part 5 / Section 3)	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	30
	Led Luminaire For Road And Street Lights (v2) Conforming To Is 10322 (part 5 / Section 3)	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	80
	Piano Type Modular Domestic Electrical Sockets - Is 1293	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	75
	Piano Type Modular Domestic Electrical Sockets - Is 1293	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	73

	Modular Piano Type Domestic Electrical Switches As Per Is 3854	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	101
	Modular Piano Type Domestic Electrical Switches As Per Is 3854	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	251
	Modular Piano Type Domestic Electrical Switches As Per Is 3854	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	98
	Modular Piano Type Domestic Electrical Switches As Per Is 3854	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	407
	Electrical Plugs (v2) Isi Marked To Is 1293	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	77
	Electrical Plugs (v2) Isi Marked To Is 1293	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	80
Group 2	Pvc Insulated Unsheathed Cable With Flexible Conductor As Per Is 694	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	500
	Led Luminaire (recessed Luminaire) (v3) Conforming To Is 10322 (part 5/section 2)	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	42
	Led Batten	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	280
	Led Batten	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	640
	Led Batten	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	340
	Led Batten	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	838
	Non - Modular Piano Type Domestic Electrical Switches As Per Is 3854	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	198
	Non - Modular Piano Type Domestic Electrical Switches As Per Is 3854	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	202
	Non - Modular Piano Type Domestic Electrical Switches As Per Is 3854	Soumen Sinha	BSO (AF) Faridabad, Complex of CWE (AF) Palam 110010	86
	Piano Type Non Modular Domestic Electrical Sockets - Is 1293	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	147
	Led Batten	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	231
	Molded Case Circuit Breakers (mccb) As Per Is / Iec 60947	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	4

Led Luminaire For Road And Street Lights (v2) Conforming To Is 10322 (part 5 / Section 3)	Upendra Nath Pandey	BSO, C/o GE (AF) Gurgaon, AF Stn Rajokri 110038	2
---	---------------------	---	---

### LED Luminaire (Recessed Luminaire) (V3) Conforming To IS 10322 (Part 5/Section 2) ( 42 pieces )

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

Bis Required	Yes
--------------	-----

#### तकनीकी विशिष्टियाँ / Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	<b>Rating of Recess type LED Luminaire/System Wattage/Rated Power (in Watt)</b>	36
	<b>Colour temperature (in K) (+/- 500 K)</b>	6000
	<b>Light Intensity (System Lumens) (in lm/watt) (hint: Total Lumen Calculation: Example: 3 W LED Rating x 80 Lumen/Watt = 240 Lumens, 3 W LED Rating x 90 Lumen / Watt = 270 Lumens, 3 W LED Rating x 100 Lumen/Watt = 300 Lumens)</b>	100
	<b>LED Chip Efficacy (in lm/watt)</b>	>/=130
	<b>Shape of the Fixture</b>	Square
	<b>Size of the Fixture</b>	600 mm x 600 mm
CONSTRUCTION	<b>Number of electronic control gear (power supplies)</b>	1
THERMAL MANAGEMENT	Maximum operating temperature (in degree C)	55
MARKING	LED Make	Other than EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA / LUMENMAX

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	42	30

**LED Batten ( 920 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>LED Batten Rating (in Watts)</b>	10.0
	<b>Length of LED Batten (Nominal) (in mm)</b>	560.0
	<b>Lamp Efficacy (Lumen / Watt), Minimum</b>	110 Or higher
	LED chip Efficacy (Lumen / Watt), Minimum	130
	Colour Temperature (in K)	6500 (Cool white)
	<b>Warranty for free replacement (in Years)</b>	1, 2, 3 Or higher
CONSTRUCTIONAL	<b>Housing Material</b>	Polycarbonate
	Colour Rendering Index (CRI) - Minimum	80 Or higher

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	280	30
2	*****	*****South West delhi	640	30

**LED Batten ( 1178 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>LED Batten Rating (in Watts)</b>	20.0
	<b>Length of LED Batten (Nominal) (in mm)</b>	1150.0
	<b>Lamp Efficacy (Lumen / Watt), Minimum</b>	100, 110 Or higher
	LED chip Efficacy (Lumen / Watt), Minimum	130
	<b>Warranty for free replacement (in Years)</b>	1, 2, 3 Or higher
CONSTRUCTIONAL	<b>Housing Material</b>	Polycarbonate
	Colour Rendering Index (CRI) - Minimum	70, 80 Or higher
	Total Harmonics (%), Maximum	15, 20 Or lower

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	340	30
2	*****	*****South West delhi	838	30

**LED Batten ( 231 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>LED Batten Rating (in Watts)</b>	18.0
	<b>Length of LED Batten (Nominal) (in mm)</b>	1150.0

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Lamp Efficacy (Lumen / Watt), Minimum</b>	100, 110 Or higher
	LED chip Efficacy (Lumen / Watt), Minimum	130
	<b>Warranty for free replacement (in Years)</b>	1, 2, 3 Or higher
CONSTRUCTIONAL	<b>Housing Material</b>	Polycarbonate
	Colour Rendering Index (CRI) - Minimum	80 Or higher
	Total Harmonics (%), Maximum	15, 20 Or lower
	Operating Voltage range (in Volts)	140 to 270

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	231	30

**Molded Case Circuit Breakers (MCCB) As Per IS / IEC 60947 ( 4 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>ISI marked</b>	YES
	<b>Rated Current (in Ampere)</b>	200A
	<b>No of poles/Protected poles(PP)</b>	4 Pole
	<b>Rated Short circuit capacity (in KA)</b>	MCCB with RSCB capacity of 10/16/25/35/50/65 KA tripping range
	<b>Breaking current (in KA)</b>	25 KA
	<b>Rated Voltage</b>	240/415 Volt 50 Hz AC

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	4	30

**LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) ( 2 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LED RATING	<b>LED Rating (in Watts)/ System Wattage/ Rated Power</b>	24
	<b>LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)</b>	120, 140 Or higher
	Color Temperature of LEDs (in K )	6500
ELECTRICAL CHARACTERISTIC	Rated voltage / Luminaire works on	220 V, 50 Hz, AC / Single phase three wires system (Phase, Neutral and Earth)
	<b>Input operating voltage range and frequency</b>	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	<b>Number of electronic control gear in the luminaire (power supplies)</b>	1, 2 Or higher
PROTECTION	The luminaire is protected against surges and transients, External, (in KV, Minimum) (hint: In case of no protection select "0")	10 Or higher

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
LUMINAIRE	<b>Provision of luminaire connecting wire along with the supply of material</b>	50 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	<b>Warranty for free replacement (in years)</b>	2, 3, 4, 5 Or higher

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	2	30

**PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 ( 500 meter )  
(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>Cable category</b>	FR
	<b>Nominal Area of Conductor (in Sq. mm)</b>	6
	Colour of core	Yellow
CONSTRUCTION	Material of conductor	Plain copper
	<b>Type of Insulation</b>	Type D

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	500	30

### LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) ( 110 pieces )

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

Bis Required	Yes
--------------	-----

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Photobiological safety of LEDs (Ref. IS 16108)	Exempt Group
LED RATING	<b>LED Rating (in Watts)/ System Wattage/ Rated Power</b>	60
	<b>LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)</b>	140 Or higher
	Color Temperature of LEDs (in K )	6500
ELECTRICAL CHARACTERISTIC	Rated voltage / Luminaire works on	220 V, 50 Hz, AC / Single phase three wires system (Phase, Neutral and Earth)
	<b>Input operating voltage range and frequency</b>	140 to 270 Volts AC at 50 Hz +/-2
CONTROL GEAR	<b>Number of electronic control gear in the luminaire (power supplies)</b>	2 Or higher
PROTECTION	The luminaire protected against surges and transients, Internal, (in KV, Minimum)	5 Or higher
LUMINAIRE	<b>Provision of luminaire connecting wire along with the supply of material</b>	50 cm (ISI marked to IS 9968)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	Warranty for free replacement (in years)	5 Or higher

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	30	30
2	*****	*****South West delhi	80	30

**LED Luminaire For Road And Street Lights (V2) Conforming To IS 10322 (Part 5 / Section 3) ( 107 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Photobiological safety of LEDs (Ref. IS 16108)	Exempt Group
LED RATING	<b>LED Rating (in Watts)/ System Wattage/ Rated Power</b>	45
	<b>LED luminaire luminous Efficacy (Lumen/watt) (Hint: Total Lumen Calculation: Example: 18 W LED Rating x 100 Lumen/Watt = 1800 Lumens, 18 W LED Rating x 120 Lumen / Watt = 2160 Lumens, 18 W LED Rating x 140 Lumen/Watt = 2520 Lumens)</b>	140 Or higher

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Color Temperature of LEDs (in K )	6500
ELECTRICAL CHARACTERISTIC	Rated voltage / Luminaire works on	220 V, 50 Hz, AC / Single phase three wires system (Phase, Neutral and Earth)
	<b>Input operating voltage range and frequency</b>	90 to 300 Volts AC at 50 Hz +/-2
CONTROL GEAR	<b>Number of electronic control gear in the luminaire (power supplies)</b>	2 Or higher
	Efficiency	? 90% (above 70 W)
PROTECTION	The luminaire protected against surges and transients, Internal, (in KV, Minimum)	5 Or higher
LUMINAIRE	<b>Provision of luminaire connecting wire along with the supply of material</b>	40 cm (ISI marked to IS 9968)
MARKING	LED Make	Other than OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND/APT
REPORTS AND CERTIFICATIONS	<b>Warranty for free replacement (in years)</b>	5 Or higher

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	60	30
2	*****	*****South West delhi	47	30

**Electrical Plugs (V2) ISI Marked To IS 1293 ( 77 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Number of poles	2 Pole
	Rated Current (in A)	16 A
	Number of Pins	3
	Plug Classification	For Class 2 Appliances

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	77	30

**Electrical Plugs (V2) ISI Marked To IS 1293 ( 80 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Number of poles	2 Pole
	Rated Current (in A)	6 A
	Number of Pins	3
	Plug Classification	For Class 2 Appliances

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	80	30

**PVC Insulated Unsheathed Cable With Flexible Conductor As Per IS 694 ( 1200 meter )****(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
STANDARDS	Product ISI Marked	Yes
GENERIC	<b>Cable category</b>	FR
	<b>Nominal Area of Conductor (in Sq. mm)</b>	4
	Colour of core	Grey
CONSTRUCTION	Material of conductor	Plain copper
	<b>Type of Insulation</b>	Type D

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	1200	30

**Piano Type Modular Domestic Electrical Sockets - IS 1293 ( 75 pieces )****(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Color of Socket Body	Grey
	<b>Socket Type Based on Existence of Shutter</b>	Without Shutter
	<b>Current Carrying Material</b>	Brass

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>According to Type of Terminal</b>	Screw Type Terminal
	Earthing Contact	With
	<b>Number of Modules</b>	2
	Degree of Protection	Socket Outlet with Normal Protection
	<b>Number of Pins</b>	3
	<b>Warranty</b>	3.0 (year)
Performance Parameters	Rated Voltage	240.0 (Volt)
	<b>Rated Current</b>	6.0 (Ampère)
Test Reports	Availability Of type Test Report To Prove Conformity to IS specifications as applicable	From Central Govt. Lab

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	75	30

**Piano Type Modular Domestic Electrical Sockets - IS 1293 ( 73 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Color of Socket Body	Grey
	<b>Socket Type Based on Existence of Shutter</b>	Without Shutter
	<b>Current Carrying Material</b>	Brass
	<b>According to Type of Terminal</b>	Screw Type Terminal
	Earthing Contact	With

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Number of Modules</b>	2
	Degree of Protection	Socket Outlet with Normal Protection
	<b>Number of Pins</b>	2
	<b>Warranty</b>	3.0 (year)
Performance Parameters	Rated Voltage	240.0 (Volt)
	<b>Rated Current</b>	16.0 (Ampère)
Test Reports	Availability Of type Test Report To Prove Conformity to IS specifications as applicable	From Central Govt. Lab

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N O.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	73	30

**Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 352 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	<b>Type of Switch</b>	1 way switch
	<b>Rated current</b>	16A
	<b>Rated voltage</b>	240.0 (Volt)
Switch classification	<b>No. of poles</b>	Single pole
	<b>According to type of terminal</b>	Screw type terminal
	<b>No. of modules</b>	1 module
Construction	<b>Current carrying material</b>	Brass
	<b>Color of switch body</b>	Grey

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Certification & standards	Availability of complete and satisfactory type test Report from Central govt/ NABL/ ILAC accredited laboratory to prove conformity to the specificatio	Yes
	Test report to be submitted to the Buyer on Demand	Yes
	<b>Warranty</b>	<b>3.0 (year)</b>

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	101	30
2	*****	*****South West delhi	251	30

**Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 505 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	<b>Type of Switch</b>	1 way switch
	<b>Rated current</b>	6A
	<b>Rated voltage</b>	240.0 (Volt)
Switch classification	<b>No. of poles</b>	Single pole
	<b>According to type of terminal</b>	Screw type terminal
	<b>No. of modules</b>	1 module
Construction	<b>Current carrying material</b>	Brass
	<b>Color of switch body</b>	Grey

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Certification & standards	Availability of complete and satisfactory type test Report from Central govt/ NABL/ ILAC accredited laboratory to prove conformity to the specificatio	Yes
	Test report to be submitted to the Buyer on Demand	Yes
	<b>Warranty</b>	<b>2.0 (year)</b>

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	98	30
2	*****	*****South West delhi	407	30

**Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 202 pieces )**  
**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	<b>Rated current</b>	6A
	<b>Nature of Switch</b>	1 way switch
	<b>Rated voltage</b>	250.0 (Volt)
Switch classification	<b>According to type of terminal</b>	Screw type terminal
	<b>No. of poles</b>	Single pole
	<b>According to type</b>	flush type
Construction	<b>Current carrying material</b>	Brass
	<b>Color of switch body</b>	Off-white
Certification & standards	Test report to be submitted to the Buyer on Demand	Yes

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Warranty	1.0 (year)

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	202	30

**Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 86 pieces )**

**(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)**

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	6A
	Nature of Switch	2 way switch
	Rated voltage	250.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Double pole
	According to type	surface type
Construction	Current carrying material	Brass
	Color of switch body	Others
Certification & standards	Test report to be submitted to the Buyer on Demand	NA
	Warranty	3.0 (year)

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	86	30

### Non - Modular Piano Type Domestic Electrical Switches As Per IS 3854 ( 198 pieces )

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

Bis Required	Yes
--------------	-----

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Rated current	16A
	Nature of Switch	1 way switch
	Rated voltage	250.0 (Volt)
Switch classification	According to type of terminal	Screw type terminal
	No. of poles	Single pole
	According to type	flush type
Construction	Current carrying material	Brass
	Color of switch body	Off-white
Certification & standards	Test report to be submitted to the Buyer on Demand	Yes
	Warranty	2.0 (year)

#### परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	198	30

### Piano Type Non Modular Domestic Electrical Sockets - IS 1293 ( 147 pieces )

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

Bis Required	Yes
--------------	-----

**तकनीकी विशिष्टियाँ /Technical Specifications**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rated Voltage	240.0 (Volt)
	<b>Rated Current</b>	<b>16.0 (Ampère)</b>
Generic	Color of socket body	Off White
	<b>Socket type based on existence of shutter</b>	With Shutter
	<b>Current Carrying Material</b>	Brass
	<b>According to type of Terminal</b>	Screwless Type Terminal
	Earthing Contact	With
	<b>Number of Modules</b>	1
	<b>Number of Poles</b>	2
	Degree of Protection	Socket Outlet with Normal Protection
	<b>Number of Pins</b>	2
	<b>Warranty</b>	<b>2.0 (year)</b>
Test Reports	Availability Of type Test Report To Prove Conformity to IS specifications as applicable	From Central Govt. Lab, NABL Accredited Lab, ILAC Accredited Lab, NA

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****South West delhi	147	30

**क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions****1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the

additional time shall commence from the last date of extended delivery period. The additional delivery time shall be  $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$ , subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

## 2. Sample Clause

After award of contract – Successful Bidder shall have to get advance sample approved from buyer before bulk manufacturing / starting bulk supplies. Successful Bidder shall submit

5

samples for Buyer's approval, within 7 days of award of contract. Buyer shall, as per contract specifications framework, either approve the advance sample or will provide complete list of modification required in the sample within 10 days of receipt of advance sample. Seller shall be required to ensure supply as per approved sample with modifications as communicated by Buyer. If there is delay from buyer side in approval of advance sample – the delivery period shall be refixed without LD for the period of delay in sample approval. In case, the sample is found to have major deviations / not conforming to the Contract specifications, the buyer at its discretion may call for fresh samples for approval before allowing bulk supplies or may terminate the contract after notifying the deviations to the seller.

Unless otherwise provided in the contract, all samples required for test shall be supplied by the contractor free of cost. Where under the contract, the contractor is required to submit an advance sample, any expenses incurred by the contractor on or in connection with the production of stores in bulk, before the sample has been approved unconditionally shall be borne by the Seller and he shall not claim any compensation in the event of such sample being found unacceptable by the Buyer / Consignee.

## 3. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

1. Bidder shall submit the following documents along with their bid for Vendor Code creation

- a. Copy of PAN Card
- b. Copy of GSTN
- c. Copy of Cancelled Cheque
- d. Copy of EFT Mandate duly certified by Bank

2. Prospective bidder shall quote for the make/ brands of cable KEI/ Havells/ Plaza/ Finolex/ Anchor, for LED lights Wipro/ Bajaj/ Orient/ Crompton/ Philips, for MCB/MCCB Legrand / Havells / HCL / C&S/ L&T for Modular Switch and Socket Anchor/ Cona/ Havells/ Legrand and for Non Modular Switch/ Socket/ Plug top Anchor/ Cona/ Havells or equivalent make brand approved by HQ Command/ E-in-C's Branch in Group-1 category and must upload product approval letter of aforesaid authority along with technical bid documents

.

## 4. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

## अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum

issued by DPIIT in this regard.

2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---