

**बिड दस्तावेज़ / Bid Document**

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	02-03-2026 17:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	02-03-2026 17:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	150 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Gujarat
विभाग का नाम/Department Name	Panchayats And Rural Housing Department Gujarat
संगठन का नाम/Organisation Name	Vikaspeth - District Panchayat Junagadh
कार्यालय का नाम/Office Name	Panchayat
कुल मात्रा/Total Quantity	1
वस्तु श्रेणी /Item Category	Reverse Osmosis based Water Treatment System above 50 LPH Capacity (V2) (Q2)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1

**बिड विवरण/Bid Details**

दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / <b>Number of days for which Bid would be auto-extended</b>	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / <b>Number of Auto Extension count</b>	1
विगत प्रदर्शन / <b>Past Performance</b>	50 %
बिड से रिवर्स नीलामी सक्रिय किया/ <b>Bid to RA enabled</b>	Yes
रिवर्स नीलामी योग्यता नियम/ <b>RA Qualification Rule</b>	50% Lowest Priced Technically Qualified Bidders
बिड का प्रकार/ <b>Type of Bid</b>	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय / <b>Time allowed for Technical Clarifications during technical evaluation</b>	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ <b>Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)</b>	No
<b>Payment Timelines</b>	Payments shall be made to the Seller within <b>15</b> days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
<b>मूल्यांकन पद्धति/Evaluation Method</b>	Total value wise evaluation
<b>मध्यस्थता खंड/Arbitration Clause</b>	No
<b>सुलह खंड/Mediation Clause</b>	No

**ईएमडी विवरण/EMD Detail**

आवश्यकता/Required	No
-------------------	----

**ईपीबीजी विवरण /ePBG Detail**

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

**एमएसई खरीद वरीयता/MSE Purchase Preference**

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

**एमआईआई खरीद वरीयता/MII Purchase Preference**

एमआईआई खरीद वरीयता/MII Purchase Preference

No

1. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

2. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

3. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

## Reverse Osmosis Based Water Treatment System Above 50 LPH Capacity (V2) ( 1 pieces )

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	<b>Construction RO Frame</b>	SS202 or better, SS304 or better Or higher
	<b>Construction of Body / Encloser</b>	NA - Being without encloser, Food Grade Plastic or Better, SS202 or better, SS304 or better Or higher
	<b>Construction of Self Contained Water Cooler</b>	Self Contained Water Cooler as per IS 1475 (ISI Marked) of cooling capacity - 150 LPH at Rated conditions and Storage Capacity 150 Liters (I,e 150/150 water cooler.)
Features and Performance	<b>Mounting type</b>	Freestanding
	<b>Filtration capacity (In LPH)</b>	Above100 LPH and upto 250 LPH
	<b>Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured</b>	upto1500
	<b>Storage Water Tank (Inclusive in the scope of Supply)</b>	Yes

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Storage Tank Material</b>	Stainless Steel or Same as body material
	<b>Guaranteed output water quality</b>	As per IS 10500 or better
Service, Warranty, Installation and Commissioning	<b>Comprehensive warranty for complete unit</b>	1 year from the date of satisfactory commissioning of the machine
	<b>Minimum Free Services during Comprehensive warranty / CMC / AMC for complete unit</b>	4 nos. per year
	<b>Installation and Commissioning inclusive in the scope of supply</b>	Yes
	<b>Training and Demonstration</b>	The installation and demonstration of the machine at the consignee place shall be carried out as part of installation and commissioning

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chudasama Rajesh Amilal	362220,Taluka Panchayat, Aazad Culb Ground ,Keshod	1	15

**Special terms and conditions-Version:1 effective from 03-04-2025 for category Reverse Osmosis based Water Treatment System above 50 LPH Capacity (V2)**

**1. Standard Terms and Conditions for Reverse Osmosis based Water Treatment System / Machine above 50 LPH Capacity**

**Scope of standard installation and commissioning for Reverse Osmosis based Water Treatment System / Machine above 50 LPH Capacity**

**1. Sellers Responsibility:**

1. All the required tools and machinery as required for installation and commissioning of machine.
2. Suitable hardware including brackets / screws washers etc., for mounting and fitting of machine at the respective locations.
3. All the water connections / fittings piping shall be laid neatly, tidily and securely as per best industry practices.
4. They provide necessary piping and connections from inlet and outlet of the machine within 2~3 meters.
5. All electrical wiring / connection to ensure proper functioning of the machine.
6. All parts of the machine should be suitably earthed, and all electric wiring should be suitably insulated to avoid electric shock during usage.
7. During Service visits with a Comprehensive Warranty / CMC the following shall be applicable .
8. Changing of Pre-Filter during each visit free of cost.

9. Cleaning of the complete water purifications system along with the water tank (if applicable).
10. Changing of Complete Filters once a year free of cost which may include but not limited to Sand Filter, Sediment Filter, Carbon Filter, Mineral Filter, Micron Filter, Anti-Scaling, Alkaline Filter, Flushing Mechanism, Reject Water Control Mechanism, Mineralizer/Taste Enhancer Media, Activated Carbon Media, etc. (as applicable).
11. Seller shall ensure that the "Actual Filtration capacity (In LPH)" specified by them shall be in line with "Filtration capacity (In LPH)". In case any contradiction is observed the superior value out of two shall reveal.

## 2. Buyers Responsibility:

1. To provide all gate passes for the installation team to access the area where installation to be carried out.
2. To provide suitable location for installation of machine which having required and easy access during installation and post installation maintenance. Any civil work shall be responsible for buyer
3. To ensure inlet water supply within 2~3 meters of machine input and machine output.
4. To provide suitable power sockets within 1~2 meters of the machine.
5. To provide potable water of reasonable quality without having muddy appearance, solids and wastes etc. The input water is usually supplied from local municipalities or PHED supplies.
6. The Input water Head (pressure) shall be 0.3 kg (3-meter head).

## 3. Note to Sellers:

1. Seller may refer to GTC and ensure strict compliance of the uploaded/ offered product which shall be in line with their model having the claimed specifications in the catalogue or better.

2. Also, same model shall not be uploaded across catalogues with unreasonable/ contradictory offerings.

3. Sellers should note that while uploading the catalogue, all three images must be distinct.

1. **Image 1 - Should be Isometric View of the Complete Product**

2. **Image 2 - Front View of the Complete Product**

3. **Image 3 - LHS or RHS view of the Complete Product**

4. In case any discrepancy is observed in the offered/ uploaded products, OEM dashboard of the respective Brand may be removed, and account shall be suspended as per IM policy.

## 4. Note to Buyer:

1. For Procurement through BID/RA: - Buyers are advised to create bid with a specific value of Golden Parameter such as Mounting Type, Filtration capacity (In LPH), Maximum Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured, Storage Tank Material, Storage Tank Capacity (In Liter), etc as applicable. Any bid created by the buyer without selecting specific LOV's or selecting Any Value in the above Golden Parameters will be treated as vague and is liable to be cancelled by competent authority at any point of time or if the above is resulting into limited competition or higher cost to the ex-chequer, the buyer will be solely responsible.
2. For Procurement through Direct / L1: - Buyers are advised to apply all filters and selections allowing all the values which are considered meeting or are better than their technical requirements. For example, Constructional Feature if the requirement is Complete Frame made of SS304 or better, buyer should select other superior values i.e. Complete Frame with encloser made of SS304 or better, such selection will act as Complete Frame made of SS304 or better (in L1 buying). For any violation of the above if resulting into limited competition or higher cost to the ex-chequer, the Buyer shall be solely
3. Buyers should also refer to GTC Clause 4. xiii.(w). The ATC / additional specification if any added by the buyer shall not be contradictory to the GeM category specifications / technical parameters (TP). Bids with contradictory specifications and technical parameters will be treated as vague and is liable to be cancelled by competent authority at any point of time or if the above is resulting into limited competition or higher cost to the ex-chequer, the buyer will be solely responsible.
4. Buyer/ consignee shall verify all the technical parameters and specifications including but limited to Filtration capacity (In LPH), Type of Machine and other related parameters of the supplied and installed machine as per contract before issuing
5. Buyers may consider EPBG for duration higher than machine warranty, which may be enchased for inadequate warranty support.

## क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/**Buyer Added Bid Specific Terms and Conditions**

### 1. **Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be  $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$ , subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

### 2. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

## अस्वीकरण/**Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional

terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---