

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	03-03-2026 15:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	03-03-2026 15:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Science And Technology
विभाग का नाम/Department Name	Department Of Science And Technology (dst)
संगठन का नाम/Organisation Name	International Advanced Research Centre For Powder Metallurgy And New Materials
कार्यालय का नाम/Office Name	Hyderabad
कुल मात्रा/Total Quantity	4
वस्तु श्रेणी /Item Category	Online UPS (>10 KVA) With Battery (Q2)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover	Yes Complete
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)

बिड विवरण/Bid Details	
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन / Past Performance	80 %
बिड से रिवर्स नीलामी सक्रिय किया/ Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/ RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
बिड का प्रकार/ Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/ Primary product category	Online UPS (>10 KVA) With Battery
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय / Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य / Estimated Bid Value	2000000
मूल्यांकन पद्धति/ Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/ Arbitration Clause	No
सुलह खंड/ Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	100000

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	26

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

Director

International Advanced Research Centre for Powder Metallurgy and New Materials, ARCI, post office balapur
hyderabad telangana

(Dr. R. Vijay)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
4. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023. [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.
5. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.
6. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.
7. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

8. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

Online UPS (>10 KVA) With Battery (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rating (in KVA)	20
	Input Voltage (AC, 50 Hz)	Three Phase, 300 V - 450V
	Output Voltage (AC, 50 Hz)	Three Phase, 415V±1% (Variable range: 380V - 415V)
Construction	Availability of Inbuilt Isolation Transformer	Yes
Battery/Backup Bank	Type of Battery	SMF-VRLA (Sealed Maintenance Free-Valve Regulated Lead Acid) / Stationary Lead Acid Batteries
	Backup Time	30.0 (minute)

Additional Specification Parameters - Online UPS (>10 KVA) With Battery (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Supply, Installation and commissioning of 20KVA 3 phase online UPS system	General: Online Double Conversion UPS Capacity: 20 KVA Insulated Gate Bipolar Transistor (IGBT) based Pulse width Modulation (PWM) with Digital Signal Processing (DSP) control To Provide uninterrupted clean power to circuit laboratory or equipment loads Static bypass to stand-by supply with auto static bypass switch
Electrical Input supply and Electrical Output supply	Input Voltage: 3 phase 400VAC plus or minus 15 percentage frequency: 50Hz Power factor: Greater than or equal to 0.99 THDi: Less than or equal to 5 percentage soft start capability for mains protection : Output Power: 20 kVA or 18kW or higher Output voltage: 3 phase 400/415 V AC (Settable to 400/415 VAC) Output Frequency: 50Hz (plus or minus 0.1 Hz in battery mode) Output Wave form: Pure sine wave Output Power factor: Greater than or equal to 0.9

Specification Parameter Name	Bid Requirement (Allowed Values)
Battery and Protection Features	External batteries Battery Type: SMF VRLA, sealed maintenance free batteries DC Bus Voltage: Suitable to system design (To be declared by OEM) Battery backup: Minimum 30 min at full load Interconnecting Cables: Included Powder coated mild steel anti static rack for batteries: Included Protection Features: Overload, short circuit protection Battery deep discharge and over charge protection Surge and spike protection Automatic and manual bypass Fault alarms with indicators
Monitoring and Display and	LCD or LED display with input and output voltage and current Load percentage Battery status Events and Alarms Forced air cooled Operating temperature: 0 to 40 degrees Celsius Ventilation space to be ensured by suppliers recommendation Noise level: Less than or equal to 55 dB at 1 meter Cabinet: floor mount powder coated industrial enclosure Standards and Certifications: Compliance: IEC 62040 or equivalent international standards OEM must be ISO 9001 and ISO 14001 certified
Warranty and Support	Warranty and Support: Minimum 2 year comprehensive warranty for UPS Minimum 2 year warranty for batteries Local service support with response within 24 hours Documentation: OEM test reports Operation and maintenance manual Wiring diagram and battery sizing details

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Narendra Kumar Bhakta	500005,Balapur Post, RCI Road, Hyderabad	2	30

Online UPS (>10 KVA) With Battery (2 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rating (in KVA)	20
	Input Voltage (AC, 50 Hz)	Three Phase, 300 V - 450V
	Output Voltage (AC, 50 Hz)	Single Phase, 230V±1%,
Construction	Availability of Inbuilt Isolation Transformer	Yes
	Minimum Overload Capacity of Online UPS	120% of Rating in KVA for 10 minutes
Battery/Backup Bank	Type of Battery	SMF-VRLA (Sealed Maintenance Free-Valve Regulated Lead Acid) / Stationary Lead Acid Batteries

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Backup Time	30.0 (minute)

Additional Specification Parameters - Online UPS (>10 KVA) With Battery (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
2. Supply and installation of 20KVA single phase online UPS system	Technical specifications: General: Online Double Conversion UPS Capacity: 20 KVA Insulated Gate Bipolar Transistor (IGBT) based Pulse width Modulation (PWM) with Digital Signal Processing (DSP) control To Provide uninterrupted clean power to circuit laboratory or equipment loads Static bypass to stand-by supply with auto static bypass switch
Electrical Input supply and Electrical Output supply	Electrical Input supply: Input Voltage: 3 phase 400VAC plus or minus 15 percentage frequency: 50Hz Power factor: Greater than or equal to 0.99 THDi: Less than or equal to 5 percentage soft start capability for mains protection Output Power: 20 kVA or 18kW or higher Output voltage: single phase 220V AC Output Frequency: 50Hz (plus or minus 0.1 Hz in battery mode) Output Wave form: Pure sine wave Output Power factor: Greater than or equal to 0.9
Battery and Protection Features:	Battery: External batteries Battery Type: SMF VRLA, sealed maintenance free batteries DC Bus Voltage: Suitable to system design (To be declared by OEM) Battery backup: Minimum 30 min at full load Interconnecting Cables: Included Powder coated mild steel anti static rack for batteries: Included Protection Features: Overload, short circuit protection Battery deep discharge and over charge protection Surge and spike protection Automatic and manual bypass Fault alarms with indicators
Monitoring and Display and Environmental and Mechanical	LCD or LED display with input and output voltage and current Load percentage Battery status Events and Alarms Forced air cooled Operating temperature: 0 to 40 degrees Celsius Ventilation space to be ensured by suppliers recommendation Noise level: Less than or equal to 55 dB at 1 meter Cabinet: floor mount powder coated industrial enclosure Standards and Certifications: Compliance: IEC 62040 or equivalent international standards OEM must be ISO 9001 and ISO 14001 certified
Warranty and Support:	Warranty and Support: Minimum 2 year comprehensive warranty for UPS Minimum 2 year warranty for batteries Local service support with response within 24 hours Documentation: OEM test reports Operation and maintenance manual Wiring diagram and battery sizing details

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Narendra Kumar Bhakta	500005,Balapur Post, RCI Road, Hyderabad	2	30

Special terms and conditions-Version:1 effective from 04-09-2025 for category Online UPS (>10 KVA) With Battery

1. In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable with reference to Installation and Commissioning.

Note to Seller: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Note to Buyer: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer and Seller as applicable.

2. The type of battery shall comply with the relevant BIS/IEC standard. (IS 15549/IS 13369 for Lead Acid Batteries and IS 16046 (Part 2)/IEC 62133-2 for Lithium-Ion Batteries.)

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

3. OEM

IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

4. Warranty

Warranty period of the supplied products shall be 2 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

5. Warranty

Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement

indicated in the relevant clause of the bid.

6. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1. Supply, Installation and commissioning of 20KVA 3 phase online UPS system

Technical specifications:

General:

Online Double Conversion UPS

Capacity: 20 KVA

Insulated Gate Bipolar Transistor (IGBT) based Pulse width Modulation (PWM) with Digital Signal Processing (DSP) control

To Provide uninterrupted clean power to circuit laboratory or equipment loads

Static bypass to stand-by supply with auto static bypass switch

Electrical Input supply:

Input Voltage: 3 phase 400VAC plus or minus 15 percentage

frequency: 50Hz

Power factor: Greater than or equal to 0.99

THDi: Less than or equal to 5 percentage

soft start capability for mains protection

Electrical Output supply:

Output Power: 20 kVA or 18kW or higher

Output voltage: 3 phase 400/415 V AC (Settable to 400/415 VAC)

Output Frequency: 50Hz (plus or minus 0.1 Hz in battery mode)

Output Wave form: Pure sine wave

Output Power factor: Greater than or equal to 0.9

Battery:

External batteries

Battery Type: SMF VRLA, sealed maintenance free batteries

DC Bus Voltage: Suitable to system design (To be declared by OEM)

Battery backup: Minimum 30 min at full load

Interconnecting Cables: Included

Powder coated mild steel anti static rack for batteries: Included

Protection Features:

Overload, short circuit protection

Battery deep discharge and over charge protection

Surge and spike protection

Automatic and manual bypass

Fault alarms with indicators

Monitoring and Display:

LCD or LED display with

input and output voltage and current

Load percentage

Battery status

Events and Alarms

Forced air cooled

Operating temperature: 0 to 40 degrees Celsius

Ventilation space to be ensured by suppliers recommendation

Noise level: Less than or equal to 55 dB at 1 meter

Cabinet: floor mount powder coated industrial enclosure

Standards and Certifications:

Compliance: IEC 62040 or equivalent international standards

OEM must be ISO 9001 and ISO 14001 certified

Warranty and Support:

Minimum 2 year comprehensive warranty for UPS

Minimum 2 year warranty for batteries

Local service support with response within 24 hours

Documentation:

OEM test reports

Operation and maintenance manual

Wiring diagram and battery sizing details

2. Supply and installation of 20KVA single phase online UPS system

Technical specifications:

General:

Online Double Conversion UPS

Capacity: 20 KVA

Insulated Gate Bipolar Transistor (IGBT) based Pulse width Modulation (PWM) with Digital Signal Processing (DSP) control

To Provide uninterrupted clean power to circuit laboratory or equipment loads

Static bypass to stand-by supply with auto static bypass switch

Electrical Input supply:

Input Voltage: 3 phase 400VAC plus or minus 15 percentage

frequency: 50Hz

Power factor: Greater than or equal to 0.99

THDi: Less than or equal to 5 percentage

soft start capability for mains protection

Electrical Output supply:

Output Power: 20 kVA or 18kW or higher

Output voltage: single phase 220V AC

Output Frequency: 50Hz (plus or minus 0.1 Hz in battery mode)

Output Wave form: Pure sine wave

Output Power factor: Greater than or equal to 0.9

Battery:

External batteries

Battery Type: SMF VRLA, sealed maintenance free batteries

DC Bus Voltage: Suitable to system design (To be declared by OEM)

Battery backup: Minimum 30 min at full load

Interconnecting Cables: Included

Powder coated mild steel anti static rack for batteries: Included

Protection Features:

Overload, short circuit protection
Battery deep discharge and over charge protection
Surge and spike protection
Automatic and manual bypass
Fault alarms with indicators

Monitoring and Display:

LCD or LED display with
input and output voltage and current
Load percentage
Battery status
Events and Alarms

Environmental and Mechanical:

Forced air cooled
Operating temperature: 0 to 40 degrees Celsius
Ventilation space to be ensured by suppliers recommendation
Noise level: Less than or equal to 55 dB at 1 meter
Cabinet: floor mount powder coated industrial enclosure

Standards and Certifications:

Compliance: IEC 62040 or equivalent international standards
OEM must be ISO 9001 and ISO 14001 certified

Warranty and Support:

Minimum 2 year comprehensive warranty for UPS
Minimum 2 year warranty for batteries
Local service support with response within 24 hours

Documentation:

OEM test reports
Operation and maintenance manual
Wiring diagram and battery sizing details

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---