

**बिड दस्तावेज़ / Bid Document**

<b>बिड विवरण/Bid Details</b>	
बिड बंद होने की तारीख/समय / <b>Bid End Date/Time</b>	03-03-2026 17:00:00
बिड खुलने की तारीख/समय / <b>Bid Opening Date/Time</b>	03-03-2026 17:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/ <b>Bid Offer Validity (From End Date)</b>	30 (Days)
मंत्रालय/राज्य का नाम/ <b>Ministry/State Name</b>	Bihar
विभाग का नाम/ <b>Department Name</b>	Department Of Panchayati Raj
संगठन का नाम/ <b>Organisation Name</b>	Begusarai District Panchayats
कार्यालय का नाम/ <b>Office Name</b>	Gram Panchayat Amarpur
कुल मात्रा/ <b>Total Quantity</b>	2
वस्तु श्रेणी / <b>Item Category</b>	High Mast Lighting Tower for large area with LED Flood Lighting System (Q3)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/ <b>MSE Relaxation for Years of Experience and Turnover</b>	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / <b>Startup Relaxation for Years of Experience and Turnover</b>	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / <b>Minimum number of bids required to disable automatic bid extension</b>	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / <b>Number of days for which Bid would be auto-extended</b>	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / <b>Number of Auto Extension count</b>	1
बिड से रिवर्स नीलामी सक्रिय किया/ <b>Bid to RA enabled</b>	No
लागू आरसीएम/ <b>RCM Applicable</b>	Yes
बिड का प्रकार/ <b>Type of Bid</b>	Two Packet Bid

**बिड विवरण/Bid Details**

तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य /Estimated Bid Value	390000
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

**ईएमडी विवरण/EMD Detail**

आवश्यकता/Required	No
-------------------	----

**ईपीबीजी विवरण /ePBG Detail**

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

**एमआईआई खरीद वरीयता/MII Purchase Preference**

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

**एमएसई खरीद वरीयता/MSE Purchase Preference**

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned

Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25 % percentage of total quantity. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023. [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

#### जीएसटी की धारा 9(3)/Section 9(3) Of GST

Where ever RCM is applicable, sellers (Regular GST registered seller who opted out of FCM , unregistered seller, seller registered under composition scheme)will be forced to put Zero GST and GST cess in their bids. Buyer will have liability of paying the GST and GST cess to the government on the specified rate mentioned by them in this Bid.

#### जीएसटी की धारा 9(3) / Section 9(3) Of GST

Where ever RCM is applicable, sellers (Regular GST registered seller who opted out of FCM , unregistered seller, seller registered under composition scheme)will be forced to put Zero GST and GST cess in their bids. Buyer will have liability of paying the GST and GST cess to the government on the specified rate mentioned by them in this Bid.

If the buyer has mentioned MSE purchase preference in ATC then service provider is required to upload necessary documents for MSE purchase preference for verification by the buyer during evaluation.

### High Mast Lighting Tower For Large Area With LED Flood Lighting System ( 2 pieces )

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	<b>Height of High Mast Tower (in Meters)</b>	30, 20, 25, 16
	<b>Installation and commissioning (Installation and commissioning work at multiple locations shall follow as per the guidelines of State/Central Govt rules and regulations as applicable)</b>	Yes. Including Civil work at site, Yes. Excluding Civil work, No, Yes. Including civil work for mining sites (for mining sites all Electricals, winch mechanism, lamps control-gears, breakers, cables etc shall be suitable for 230 V (L-L), 50 Hz supply and with RCCB/ELCB based protection provided with suitable range to comply relevant CEA regulation 42
	<b>Onsite warranty (in Years)</b>	2, 3, 5
High mast System	<b>No of sections</b>	2, 3, 4, 5, 6
	<b>Effective length of each section (in m)</b>	10, 10.5, 8.5, 5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Material construction: The mast shall be manufactured using special steel plates, conforming to</b>	355 grade as per BSEN10 025
	<b>Bottom diameter (in mm) - Minimum</b>	610, 540, 570
	<b>Plate thickness for Middle (in mm) - Minimum</b>	4
	<b>Plate thickness for Bottom (in mm) - Minimum</b>	5, 6
	<b>No of longitudinal welds / section (in Nos)</b>	1, 2
	<b>Diameter of base plate (in mm) - Minimum</b>	840, 740, 770
	<b>Thickness of base plate (in mm) - Minimum</b>	30, 25
Wind Load	<b>Maximum Wind load</b>	47 m/sec, 50 m/sec, 55 m/sec, 62.5 m/sec
Door Opening	<b>Size of opening and closing door at base compartment of high mast (in mm) - Minimum</b>	1200 x 250, 1200 x 300
Junction Box	<b>Ingress protection for Junction Box i.e. IP Class (as per IS/IEC:60529:2001 latest) Test Report from Central Government lab/NABL/ILAC accredited lab and report shall furnish to buyer on demand</b>	IP 55, IP 65
	<b>No of core</b>	3, 4, 5
	<b>Cable category</b>	FR, FR-LSH, 1, 2
	<b>Size of cable (in Sq mm)</b>	1.5, 2.5, 4
	<b>Conductor material shall be</b>	Copper
Winch	<b>The winch shall have provision for manual operation in case of failure of the motor</b>	Yes
Stainless Steel Wire Rope	<b>The breaking load of each rope shall be at full load as per the relevant standard</b>	>/=2400 Kg, >/=2250Kg
Electrical System, Cable and Cable Connections	<b>No. of cores</b>	1, 2, 3, 4, 5
	<b>Cable shall be</b>	Armoured, Unarmoured
	<b>Conductor material shall be</b>	Copper, Aluminium
	<b>Cable Category</b>	1, C1, C2

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Incoming power cable from feeder panel to base compartment of mast and cable shall conforming to</b>	IS:7098 (Part 1):1988 latest
Feeder pillar Panel	<b>Feeder pillar panel for each mast</b>	Yes, No without feeder pillar panel
	<b>Feeder panel shall be suitable for</b>	415 V, 3 phase, 4 wire, 50 Hz, AC, 230 V, 1 phase, AC 50 Hz, 230 V (L-L), 3 phase, AC 50 Hz (for Mining area)for Mining sites all electricals, winch mechanism, lamps control-gears, breakers, cables etc shall be suitable for 230V(L-L), 50 Hz supply
	<b>The control panels shall be</b>	Stand mounted, No without feeder pillar panel
	<b>Ingress protection for feeder pillar panel i.e IP Class (as per IS/IEC:60529:2001 latest).Test Report shall furnish from Central Government lab/NABL/ILAC accredited lab to buyer on demand</b>	IP 55, IP 65, No without feeder pillar panel
	<b>It shall be fabricated out of</b>	14 SWG CRCA sheet steel, No without feeder pillar panel
	<b>Thickness of sheet (in mm)</b>	2, No without feeder pillar panel
	<b>The panels shall be given pre-treatment and powder coated and color shall be</b>	Grey, No without feeder pillar panel
	<b>The stand shall be painted in</b>	Black color, No without feeder pillar panel
	<b>Cable entry shall be at the</b>	Bottom, No without feeder pillar panel
	<b>The panels shall have</b>	knock outs of the required cable, No without feeder pillar panel
	<b>Laminated circuit diagram shall be pasted</b>	inside of the door, No without feeder pillar panel
	<b>Feeder pillar shall have pad locking arrangement</b>	Yes, No without feeder pillar panel
	<b>Earth terminal</b>	12 mm dia. Bolts, No without feeder pillar panel
	<b>Panel shall have a sloping cover to avoid accumulation of dust</b>	Yes, No without feeder pillar panel
	<b>Panel shall be provided with incoming &amp; outgoing MCCB / MCB of appropriate rating and in desired quantity depending on total no of circuits in use</b>	yes, No without feeder pillar panel

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	<b>Timer for automatic ON &amp; OFF of lights with pilot lamps shall be provided</b>	Yes, No without feeder pillar panel
	<b>Bus bars material</b>	Yes. Copper, No without feeder pillar panel
	<b>No of Cores</b>	1, 2, 3, 4, 5, No without feeder pillar panel
	<b>Size of cable (in Sq.mm)</b>	1.5, 2.5, 4, 6, 10, 16, No without feeder pillar panel
	<b>Cable Shall be</b>	Armoured, Unarmoured, No without feeder pillar panel
	<b>The conductor material shall be</b>	Copper, Aluminium, No without feeder pillar panel
	<b>cable category</b>	1, C1, C2, No without feeder pillar panel
LED FLOOD LIGHT LUMINAIRE	<b>No. of Luminaires for each high mast lighting tower (in Nos)</b>	4, 6, 8, 10, 12, 16, 18
	<b>LED Rating/System Wattage/Rated Power for each luminaire</b>	100W, 110W, 120W, 125W, 130W, 140W, 150W, 180W, 200W, 250W, 300W, 350W, 400W, 500W, 1000W
	<b>Luminaire System Efficacy (Lumen/watt)</b>	>= 100 Lm/Watt
	<b>Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest</b>	IP65, IP66, IP67
	<b>Mounting brackets (included)</b>	Adjustable
	<b>Input operating Voltage range and frequency</b>	90 to 300 Volts AC at 50Hz+/-2Hz, 140 to 270 Volts AC at 50 Hz+/-2 Hz with auto cutt off at below 120V
	<b>Rated voltage</b>	230 V AC 50 Hz, 415+/-10% V AC 50 Hz +/-5%
	<b>Colour temperature</b>	6000K (+/- 500K), 5000K (+/- 500K), 4000K (+/- 500K), 3000K (+/- 500K)
	<b>Optic lense material (UV stabilised) (Write NA for without optic lense supply)</b>	Poly carbonate lense, NA
	<b>Operating temperature range</b>	-20 deg C to +50 deg C, -10 deg C to +50 deg C, -10 deg C to +55 deg C
	<b>The luminaire shall be protected against surges and transients( Internal)</b>	>=5KV, >=4KV
	<b>Number of electronic control gear per luminaire (power supplies)</b>	1 No., 2 Nos., 3 Nos., 4 Nos.
	<b>Length of ISI marked three core wire (shall be provided along with supply of material)</b>	50 cm, 100 cm

**इनपुट कर क्रेडिट(आईटीसी) तथा रिवर्स प्रभार (आरसीएम)/Input Tax Credit(ITC) and Reverse Charge(RCM) Details**

जीएसटी पर इनपुट कर क्रेडिट /ITC on GST	जीएसटी उपकर कर क्रेडिट /ITC on GST Cess	लागू आरसीएम/R CM Applicable	रिवर्स प्रभार के अनुसार जीएसटी/GST as per RCM	रिवर्स प्रभार के अनुसार जीएसटी उपकर 1 /GST Cess 1 as per RCM	GST Cess 2 as per RCM	वैकल्पिक रिवर्स प्रभार /Optional RCM
NA	NA	Yes	12%	NA	NA	No

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Arjun Paswan	851118,PANCHAYAT OFFICE, GRAM PANCHAYAT AMARPUR, AT+PO- AMARPUR, BLOCK-BARAUNI	2	15

**क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions****1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be (Increased quantity ÷ Original quantity) × Original delivery period (in days), subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

**अस्वीकरण/Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to

exemption provided to such sellers under GeM GTC.

3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---