

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	05-03-2026 16:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	05-03-2026 16:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	15 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Finance
विभाग का नाम/Department Name	Department Of Financial Services
संगठन का नाम/Organisation Name	Lic - Life Insurance Corporation Of India
कार्यालय का नाम/Office Name	Divisional Office Jeevan Prakash Tagor Marg Rajkot
कुल मात्रा/Total Quantity	1
वस्तु श्रेणी /Item Category	Online UPS (?10 KVA) With Battery Conforming To IS 16242 (Part 1) (Q2)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	5
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days

बिड विवरण/Bid Details

निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/ Evaluation Method	Total value wise evaluation

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

बोली विभाजन लागू नहीं किया गया/Bid splitting not applied.

Online UPS (?10 KVA) With Battery Conforming To IS 16242 (Part 1) (1 pieces)

Bis Required	Yes
--------------	-----

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / [As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Performance Parameters	Rating (in KVA)	3
	Input Voltage (AC, 50 Hz)	Single Phase, 160V - 260V
	Output Voltage (AC, 50 Hz)	Single Phase, 230V±1%,
Construction	Availability of Inbuilt Isolation Transformer	Yes
	Minimum Overload Capacity of Online UPS	120% of Rating in KVA for 10 minutes
Battery/Backup Bank	Type of Battery	SMF-VRLA (Sealed Maintenance Free-Valve Regulated Lead Acid) / Stationary Lead Acid Batteries
	Backup Time	120.0 (minute)
Features	Type of Mounting of Online UPS	Floor Standing
	Ingress Protection	IP20, IP21 Or higher
Operating Conditions	Operating Temperature Range (Lower Limit)	5°C to 10°C

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Operating Temperature Range (Upper Limit)	45°C to 50°C
Warranty And Reports	Minimum Standard Warranty	1.0 (year)

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Parmar Dinesh Premjibhai	360001,L I C OF INDIA OOFICE SERVICE DEPARTMENT DIVISIONAL OFFICE JEEVAN PRAKASH TAGOR MARG RAJKOT 360001	1	15

Buyback Detail

Item Name	UPS WITH BATTERY
Item Description	5 KV UPS ALONGWITH 15 TUBULAR BATTERIES OF 150 AH FOR BUY BACK
Serial No.	78
Model	XSIS
Brand	XSIS
Year of Manufacturing	2003
Purchase On	2003-09-01
Age	
Size	5
Rating	
Quantity	1
Unit	55CM X 55 CM X 30 CM
Remark	PURCHASE OF NEW 3 KV UPS ALONGHWITH BATTERY - WITH BUY BACK OF 1 OLD 5 KVA BATTERY AND 15 150 AH TUBULAR BATTERIES
Uploaded Image	View Uploaded Image

Special terms and conditions-Version:2 effective from 06-02-2026 for category Online UPS (?10 KVA)

With Battery Conforming To IS 16242 (Part 1)

1. **1.** In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable with reference to Installation and Commissioning.

Note to Seller: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Note to Buyer: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer and Seller as applicable.

2. The type of battery shall comply with the relevant BIS/IEC standard. (IS 15549/IS 13369 for Lead Acid Batteries and IS 16046 (Part 2)/IEC 62133-2 for Lithium-Ion Batteries.)

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

A) Address and location of the branch

1)LIC OF INDIA, Mangal Murti Complex, Kalava chowk, Junagadh

Contact person – Shri Shailendrasinh M Vaghela – Mob no 98243 65690

b)Security deposit – 10% of cost. The security deposit shall be recovered from Bill and refunded after successful completion of Warranty period of 2 years. No interest on security deposit is payable at the time of refund.

c) Service level agreement – Any breakdown of UPS shall be attended within 24 hours . The break down is to be rectified within 48 hours. If any breakdown is not possible to be rectified with 48 hours the buyer has to provide standby unit at their cost.

d) Comprehensive Annual maintenance contract – The chargeable Annual Comprehensive annual maintenance contract of UPS (Excluding battery Bank) shall commence after successful completion of Warranty period of two years on following rates:-

Rs 1500.00 Per Year Per KVA (For 1st and 2nd years after Warranty)

Rs 2000.00 Per year per KVA (For 3rd and 4th Years after warranty)

Frequency of service – Quarterly

CAMC Payment: Quarterly on servicing and submission of servicing report duly signed and stamped by user. No advance Payment shall be made.

Inclusion & exclusion – The CAMC contract includes all necessary spares, labour & transportation for maintaining UPS in working condition but excluding input and output wiring, MCB DB & Batteries.

e) Installation within 3 days of delivery – penalty per day 500 for late installation beyond 3 days

f) Turn Up time – All break down to be attended within 24 hours – penalty Rs 100/ - per day if not attended within turn Up time

-

g) UPS Manufacturer – UPS is to be procured from OEM only with BIS certification.

h) Minimum Bank Solvency (Not older than Six months) – 2 Times the estimated cost

i) Average Annual Turn over of UPS work during last three Financial years ending on 31.03.2025 duly certified by Chartered Accountant – 10 times of estimated cost.

j) Experience of having successfully completed similar works in Government/ Public sector department during last 7 years ending last day of month previous to the one in which application / Bid is invited. – 1) 3 Similar works each costing not less than 40% of estimated cost. 2) 2 Similar works each costing not less than 50% of estimated cost. 3) 1 similar works each costing not less than 80% of estimated cost.

H) Old UPS and Batteries to be disposed off at your cost within 3 days of installation of UPS and batteries.

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.

2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---