

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	27-02-2026 16:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	27-02-2026 16:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	120 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Petroleum And Natural Gas
विभाग का नाम/Department Name	Indian Oil Corporation Limited
संगठन का नाम/Organisation Name	locl- Wrpl
कार्यालय का नाम/Office Name	Rajkot
कुल मात्रा/Total Quantity	36
वस्तु श्रेणी /Item Category	Supply of lightning arrestors with insulating base fittings etc. as per specifications. For 30 kV rated voltage, Highest system voltage 36 KV, 10 KA lightning arrestors , ISOLATOR Supply of 3 poles, centre post rotating type, offload motorized isolator cum earthing switch of 33kV, 800 A, 25 KA for 1 sec, rated short time current , Supply of all necessary tariff metering and equipments to be mounted at receiving end of supply in the switchyard _1 phase Outdoor type 33 kV CTs 100 to 150, 1A , Supply of all necessary tariff metering and equipments to be mounted receiving end of supply in the switchyard _1 phase Outdoor type 33 kV CTs 20 to 50, 1A , Supply of all necessary tariff metering and equipments _1 phase Outdoor type PTs as per Specifications , Supply of all necessary tariff metering and equipments_1 phase Outdoor type PTs as per Specifications , Surge counter for 33 kV surge arrester , Supply of numerical Transformer Differential Relay Make Esasergy type MICOM P 642 , 87 KVAR capacitor for 6.6 kv , 33 kV ABT meter metering purpose,0.2S class , Transformer TAP position indicator EMCO EE 601 , 44 KVAR capacitor for 6.6 kv , 131 KVAR capacitor for 6.6 kv
GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS	Lightening arrestors with insulating rings, 3 poles, centre post rotating type, offload isolator, Outdoor type 33 kV CTs 100-150/1A, 1 phase Outdoor type PTs, Surge counter for 33 kV surge arrester, Differential Relay Make - Esasergy type MICOM P 642, 87 KVAR capacitor, 33 kV ABT meter, Transformer TAP position indicator -(EMCO EE 601)
	Searched String: Lightening arrestors with insulating rings Compact Light Weight Blanket with Good Insulating Properties (MHA), Environmental Chamber, Waist Belt Nylon with Buckle and Rings for Facilitating Slithering / Rapping

बिड विवरण / Bid Details

(MHA) Smith Machine (Version 2), Asbestos Cement Pressure Pipe and Joints (V2) as per IS 1592, PVC Insulated Copper Cable Single and Multi - Core Circular Sheathed Cable with Flexible Conductor (V2) as per IS 694, Plasticized PVC Tapes with Non-Thermosetting Adhesive for electrical purpose (V2) ISI marked to IS 7809 (Part 3/ Sec1), PVC Flat Cable, Copper Conductor with PVC Insulation and Sheath as per IS 694, Spiral Wound Metallic Gasket, PVC Insulated Cables, Unsheathed with Rigid Conductor (V2) as per IS 694

Searched String: 3 poles, centre post rotating type, offload isolator

Category not available on GeM for the text string uploaded by the buyer

Searched String: Outdoor type 33 kV CTs 100-150/1A

CR Type Surge Suppressor Upto 33 kV (BHEL), XLPE Cables, Category C1 - FR, for Working Voltages from 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), 11 or 33 kV Outdoor Live Tank Current Transformer (BHEL), Voltage Transformer - Dual Purpose - Outdoor as per IS 3156, Cable Termination Kit Suitable for Cables Up to and Including 33 kV (V2), XLPE Cables for Working Voltages From 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), Vacuum Circuit Breaker - Outdoor Type - Rated Voltage up to and Including 72.5 KV as per IS 13118, Porcelain Insulators for Overhead Power Lines with A Nominal Voltage Greater than 1000 V as per IS 731, Laboratory Desiccator (V2), Correspondence Envelopes (V3) Conforming to IS 13892

Searched String: 1 phase Outdoor type PTs

Distribution Transformer, 1 Phase, Up to and including 100 kVA ISI marked to IS 1180 (Part 1), Muffle Furnace, Vacuum Circuit Breaker - Outdoor Type - Rated Voltage up to and Including 72.5 KV as per IS 13118, AC Static Watthour Meters - Energy Meter (V2) as per IS 13779, Parliament Hinges-IS:362, Mobile Storage Compactors, Elastomer Insulated, Unkinkable Flexible Cords (Workshop Type) - IS 9968 (Part 1), Modular Piano Type Domestic Electrical Switches as per IS 3854, Elastomer Insulated, Unkinkable Flexible Cords (Domestic Type) - IS 9968 (Part 1), Copper alloy Taps/Stop Valves (V2) Conforming to IS 8931

Searched String: Surge counter for 33 kV surge arrester

CR Type Surge Suppressor Upto 33 kV (BHEL), XLPE Cables for Working Voltages From 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), Leakage Current Meter / Analyser for Surge Arrester, Metal Oxide Surge Arresters Without Gaps For A.C. Systems (V2) Conforming to IS 15086 (Part 4), Xlpe Cables, Category C2 - FR - LSH, for Working Voltages From 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), SOVP Device for Street light Pole Mounted, Cable Joint Kit Suitable for Cables Up to and Including 33 kV (V2), XLPE Cables, Category C1 - FR, for Working Voltages from 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), Cable Termination Kit Suitable for Cables Up to and Including 33 kV (V2), Cancellous/Cortical Mix for Dental or Orthopaedic Surgeries

Searched String: Differential Relay Make - Esasergy type MICOM P 642

GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS

बिड विवरण / Bid Details	Category not available on GeM for the text string uploaded by the buyer
	<p>Searched String: 87 KVAR capacitor</p> <p>Capacitor Banks For Use On 11 KV System (PSPCL)), personal safety kit reflective luminous garments, A.C. Motor Capacitors ISI Marked to IS 2993 (Part 1), Composter for Solid Waste Management, Pyrogallol, Eosin Y Dissodium Salt, Ammonium carbonate, Inositol, Capacitors for Electric Fan Motors as per IS 1709 (V2), Shunt Power Capacitors (Self - Healing Type) Marked to IS 13340 (Part 1) (V2)</p> <p>Searched String: 33 kV ABT meter</p> <p>CR Type Surge Suppressor Upto 33 kV (BHEL), XLPE Cables for Working Voltages From 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), 11 or 33 kV Outdoor Live Tank Current Transformer (BHEL), XLPE Cables, Category C1 - FR, for Working Voltages from 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), Xlpe Cables, Category C2 - FR - LSH, for Working Voltages From 3.3 KV up to and Including 33 KV as per IS 7098 (Part 2), Cable Joint Kit Suitable for Cables Up to and Including 33 kV (V2), Non-Contact High Voltage Detector, Cable Termination Kit Suitable for Cables Up to and Including 33 kV (V2), Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up to and including 2500 KVA, Voltage Transformer - Dual purpose - Indoor</p> <p>Searched String: Transformer TAP position indicator - (EMCO EE 601)</p> <p>Category not available on GeM for the text string uploaded by the buyer</p>
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	<ul style="list-style-type: none"> • Distribution Transformer, 3 Phase, 11 kV > 200 KVA up to and Including 2500 KVA
बीओक्यू शीर्षक / BOQ Title	33KV Switchyard spares at WRPL Chaksu Base
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़ / Document required from seller	<p>Experience Criteria, Certificate (Requested in ATC), Additional Doc 1 (Requested in ATC), Additional Doc 2 (Requested in ATC), Additional Doc 3 (Requested in ATC), Compliance of BoQ specification and supporting document</p> <p>*In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer</p>
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है / Do you want to show documents uploaded by bidders to all bidders participated in bid?	No

बिड विवरण/Bid Details	
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Supply of all necessary tariff metering and equipments to be mounted at receiving end of supply in the switchyard _1 phase Outdoor type 33 kV CTs 100 to 150, 1A
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Item wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	21

(a) ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

Operations Manager

Indian Oil Corporation Limited, Western Region Pipelines, Phagi Road, Chaksu, Jaipur-303901 (Rajasthan)
(Hitesh Meena)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

एमआईआई के लिए सक्षम प्राधिकारी का विवरण:/Details of the Competent Authority for MII

सक्षम प्राधिकारी का नाम/Name of Competent Authority	Mr. Santanu Dhar
सक्षम प्राधिकारी का पदनाम/Designation of Competent Authority	Under Secretary to the Govt. of India
सक्षम प्राधिकारी का कार्यालय/विभाग/प्रभाग/Office / Department / Division of Competent Authority	MoPNG
सीए अनुमोदन संख्या/CA Approval Number	MoPNG Order No. FP-20013/2/2017-FP-PNG-Part(4) (E41432), dtd. 26.04.2022
सक्षम प्राधिकारी अनुमोदन तिथि/Competent Authority Approval Date	26-04-2022
सक्षम प्राधिकारी द्वारा प्रदान की गई स्वीकृति का संक्षिप्त विवरण/Brief Description of the Approval Granted by Competent Authority	Limit for PPP-MII exemption is INR One Crore as per above order issued by MoPNG.

Competent Authority Approval for not opting Make In India Preference : [View Document](#)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	100

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is

not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 100% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

मूल्यांकन विधि(मदवार मूल्यांकन विधि) / Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

मूल्यांकन अनुसूचियां / Evaluation Schedules	वस्तु/श्रेणी / Item/Category	मात्रा / Quantity
Schedule 1	Supply Of Lightning Arrestors With Insulating Base Fittings Etc. As Per Specifications. For 30 Kv Rated Voltage, Highest System Voltage 36 Kv, 10 Ka Lightening Arrestors	2
Schedule 2	Isolator Supply Of 3 Poles, Centre Post Rotating Type, Offload Motarized Isolator Cum Earthing Switch Of 33kv, 800 A, 25 Ka For 1 Sec, Rated Short Time Current	2
Schedule 3	Supply Of All Necessary Tarrif Metering And Equipments To Be Mounted At Receiving End Of Supply In The Switchyard _1 Phase Outdoor Type 33 Kv Cts 100 To 150, 1a	2
Schedule 4	Supply Of All Necessary Tarrif Metering And Equipments To Be Mounted Receiving End Of Supply In The Switchyard _1 Phase Outdoor Type 33 Kv Cts 20 To 50, 1a	1
Schedule 5	Supply Of All Necessary Tarrif Metering And Equipments _1 Phase Outdoor Type Pts As Per Specifications	2
Schedule 6	Supply Of Lightning Arrestors With Insulating Base Fittings Etc. As Per Specifications. For 30 Kv Rated Voltage, Highest System Voltage 36 Kv, 10 Ka Lightening Arrestors	3
Schedule 7	Supply Of All Necessary Tarrif Metering And Equipments_1 Phase Outdoor Type Pts As Per Specifications	3
Schedule 8	Surge Counter For 33 Kv Surge Arrester	8
Schedule 9	Supply Of Numerical Transformer Differential Relay Make Esasergy Type Micom P 642	1
Schedule 10	87 Kvar Capacitor For 6.6 Kv	3
Schedule 11	33 Kv Abt Meter Metering Purpose,0.2s Class	2
Schedule 12	Transformer Tap Position Indicator Emco Ee 601	1
Schedule 13	44 Kvar Capacitor For 6.6 Kv	3
Schedule 14	131 Kvar Capacitor For 6.6 Kv	3

Supply Of Lightning Arrestors With Insulating Base Fittings Etc. As Per Specifications. For 30 KV Rated Voltage, Highest System Voltage 36 KV, 10 KA Lightning Arrestors

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bhanu Prakash Srivastava	303904,Indian Oil Corporation Limited, Western Region Pipelines, Mohanpura, ,Khasra No: 725/1,Mohanpura Prithvi Singh,Tehsil: Phagi, Distt. Jaipur-303904 Rajasthan	2	120

ISOLATOR Supply Of 3 Poles, Centre Post Rotating Type, Offload Motarized Isolator Cum Earthing Switch Of 33kV, 800 A, 25 KA For 1 Sec, Rated Short Time Current

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
---------------	---	-------------	------------------	------------------------------

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bhanu Prakash Srivastava	303904,Indian Oil Corporation Limited, Western Region Pipelines, Mohanpura, ,Khasra No: 725/1,Mohanpura Prithvi Singh,Tehsil: Phagi, Distt. Jaipur-303904 Rajasthan	2	120

**Supply Of All Necessary Tarrif Metering And Equipments To Be Mounted At Receiving
End Of Supply In The Switchyard _1 Phase Outdoor Type 33 KV CTs 100 To 150, 1A**

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bhanu Prakash Srivastava	303904,Indian Oil Corporation Limited, Western Region Pipelines, Mohanpura, ,Khasra No: 725/1,Mohanpura Prithvi Singh,Tehsil: Phagi, Distt. Jaipur-303904 Rajasthan	2	120

**Supply Of All Necessary Tarrif Metering And Equipments To Be Mounted Receiving
End Of Supply In The Switchyard _1 Phase Outdoor Type 33 KV CTs 20 To 50, 1A**

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bhanu Prakash Srivastava	303904,Indian Oil Corporation Limited, Western Region Pipelines, Mohanpura, ,Khasra No: 725/1,Mohanpura Prithvi Singh,Tehsil: Phagi, Distt. Jaipur-303904 Rajasthan	1	120

**Supply Of All Necessary Tarrif Metering And Equipments _1 Phase Outdoor Type PTs
As Per Specifications**

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bhanu Prakash Srivastava	303904,Indian Oil Corporation Limited, Western Region Pipelines, Mohanpura, ,Khasra No: 725/1,Mohanpura Prithvi Singh,Tehsil: Phagi, Distt. Jaipur-303904 Rajasthan	2	120

**Supply Of Lightning Arrestors With Insulating Base Fittings Etc. As Per Specifications.
For 30 KV Rated Voltage, Highest System Voltage 36 KV, 10 KA Lightening Arrestors**

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	3	120

**Supply Of All Necessary Tarrif Metering And Equipments_1 Phase Outdoor Type PTs
As Per Specifications**

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	3	120

Surge Counter For 33 KV Surge Arrester

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	8	120

Supply Of Numerical Transformer Differential Relay Make Esasergy Type MICOM P 642

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	1	120

87 KVAR Capacitor For 6.6 Kv

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	3	120

33 KV ABT Meter Metering Purpose,0.2S Class

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	2	120

Transformer TAP Position Indicator EMCO EE 601

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	1	120

44 KVAR Capacitor For 6.6 Kv

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	3	120

131 KVAR Capacitor For 6.6 Kv

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Chetan Kumar Choudhary	303901,Indian Oil Corp Ltd, Western region Pipelines, Phagi Road, Chaksu, Jaipur Dist,Rajasthan	3	120

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

3. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

LIST OF DOCUMENTS TO BE SUBMITTED BY BIDDER

I. Pre-Qualification Criteria (Single Order Value Criteria)

The bidder should have successfully executed Purchase Orders (for similar item) during the last five years ending on the last day of the month immediately preceding the month in which the original bid submission end date falls for this tender.

Similar item definition: "Supply of 6.6 kV and above electrical equipments."

The bidder needs to submit self-attested copies of PO along with proof of execution as mentioned below.

Particulars	Order Value
One executed order for similar item costing (on landed cost basis including P&F, taxes duties & freight) not less than the value:	₹ 9,46,610.00
Two executed orders for similar item costing (on landed cost basis including P&F, taxes duties & freight) not less than the value:	₹ 7,57,288.00

Three executed orders for similar item costing (on landed cost basis including P&F, taxes duties & freight) not less than the value:

₹ 5,67,966.00

Bidder is required to submit following documents towards execution of previous purchase order(s) along with its Execution Proof:

- a) Purchase Order,**
- b) Completion Certificate/ GeM CRAC Certificate,**
- c) Invoice(s),**
- d) Payment Receipts/Bank Statements,**
- e) Delivery Proofs/ Delivery Challan / Lorry Receipts etc.**

- II. Duly signed and stamped copies of Technical Specifications as per GeM Bid/ Tender Document.**
- III. Documents/certificates to be submitted as required in Technical Specifications**
- IV. Duly Signed and Stamped Copy of IOCL Tender Document PWCHM25008R.**
- V. All applicable Annexures duly filled signed and stamped by authorized signatory**
- VI. UDYAM certificate /MSME/NSIC/ Registration certificate.**
- VII. PAN Card.**
- VIII. GST Certificate - Goods and Service Tax Registration Certificate.**

Furthermore, bidder is required to take note of following:

1. Bidder is requested to refer **Buyer Added Bid Specific ATC Document** (Tender Document PWCHM25008R) containing NIT, Technical Specifications, Annexures, Tender terms & conditions etc. Bidder must go through the same and submit their offer according to the same. Bidder is also required to **submit duly filled , signed and stamped copy of IOCL Tender Document PWCHM25008R.**
2. **The supplied material must conform to specifications as per** Technical Specification document available in Tender document PWCHM25008R. Bidder must submit duly signed and scanned copy of Technical Specifications. **If bidder's offered product fails to meet the technical specifications, the same shall be liable for rejection.**
3. **Bidder must submit duly filled, signed and stamped copy of All Annexures as per Section III of IOCL tender document.**
4. Security deposit /**Performance Bank Guarantee @5%** of contract value shall be applicable. Said **Security deposit /Performance Bank Guarantee shall be valid for a period of 18 months plus 3 months claim period** from date of supply of material at owner's station.
5. ~~IOCL nominated Third Party Pre-dispatch Inspection is Applicable for this contract. QAP should be submitted by the successful bidder within 07 days of issuance of GEM contract for review and approval of IOCL. Inspection will be required out by IOCL/ IOCL approved agency.~~
6. Consignee location mentioned in **Section IV- Bill of Quantity (BOQ)** of IOCL Tender Document PWCHM25008R. Kindly note that **actual delivery location for supply of material** (including installation and commissioning) shall be as per Section IV- Bill of Quantity (BOQ)-IOCL Tender Document PWCHM25008R.

7. IN THE EVENT OF AN IRRECONCILABLE CONFLICT BETWEEN THE PROVISION OF THE TENDER DOCUMENTS (INCLUDING IOCL GENERAL CONDITIONS OF PURCHASE) AND GEM GENERAL TERMS & CONDITIONS, THE PROVISION(S) IN THE TENDER DOCUMENTS (INCLUDING IOCL GENERAL CONDITIONS OF PURCHASE) SHALL SUPERSEDE THE CONFLICTING PROVISION(S) IN THE GEM GENERAL TERMS & CONDITIONS.

All other terms and conditions shall be applicable per GeM General Terms and conditions.

4. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

5. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- a. Copy of PAN Card.
- b. Copy of GSTIN.
- c. Copy of Cancelled Cheque.
- d. Copy of EFT Mandate duly certified by Bank.

6. Generic

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

7. Generic

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

8. Generic

1. The Seller shall not assign the Contract in whole or part without obtaining the prior written consent of buyer.
2. The Seller shall not sub-contract the Contract in whole or part to any entity without obtaining the prior written consent of buyer.
3. The Seller shall, notwithstanding the consent and assignment/sub-contract, remain jointly and severally liable and responsible to buyer together with the assignee/ sub-contractor, for and in respect of the due performance of the Contract and the Sellers obligations there under.

9. Generic

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.

- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

10. **Generic**

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

11. **Purchase Preference (Centre)**

Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 100% of total value.

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional

terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---