

**बिड दस्तावेज़ / Bid Document**

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	06-03-2026 18:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	06-03-2026 18:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Defence
विभाग का नाम/Department Name	Department Of Defence Production
संगठन का नाम/Organisation Name	Munitions India Limited
कार्यालय का नाम/Office Name	*****
कुल मात्रा/Total Quantity	1
वस्तु श्रेणी /Item Category	Power Generator - DG Set (up to 900 KVA) (Q2)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	21 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)/OEM Average Turnover (Last 3 Years)	21 Lakh (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

बिड विवरण/Bid Details	
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	4 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	Yes ( <a href="#">Arbitration clause document</a> ) as per DoE OM No.F.1/2/2024-PPD dated 03.06.2024 Arbitration should not be routinely included in contracts
सुलह खंड/Mediation Clause	No

#### ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	135180

#### ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00

ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).

30

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

**लाभार्थी /Beneficiary :**

Munitions India Limited, Ordnance Factory Itarsi  
Ordnance Factory Itarsi , A Unit of Munitions India Limited , Dist- Narmadapuram. Madhya Pradesh -461122  
(Munitions India Limited, Ordnance Factory Itarsi)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

**एमआईआई खरीद वरीयता / MII Purchase Preference**

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

**एमएसई खरीद वरीयता/MSE Purchase Preference**

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में हो / Purchase Preference to MSE OEMs available upto price within L1+X%	15

सूक्ष्म और लघु उद्यम को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MSE purchase preference	25
---	----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
2. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
3. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023. [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.
4. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.
5. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.
6. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting

bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

### Power Generator - DG Set (up To 900 KVA) ( 1 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

#### तकनीकी विशिष्टियाँ /Technical Specifications

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Power Generator INSTALLATION CONFIGURATIONS	<b>Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)</b>	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	<b>Nominal Rated Capacity (kVA)</b>	500
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase
ENGINE	<b>Rated Engine Power (kWm)</b>	110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency Or higher
	Type of Engine cooling	Liquid Cooled
	<b>Type of governer</b>	Electronic Or higher
	Number of cylinders (nos)	6
	<b>Rated RPM of Engine (RPM)</b>	1500
	<b>Fuel</b>	High Speed Diesel (HSD)
	Starting voltage (volt)	24
	Salient Features of Engine	Turbo Charged Engine, Naturally aspirated engine, Direct injection Fuel System, CRDi Fuel System, cold start upto (-20 deg c ), No derating applicable upto 4500 above MSL of altitude at 25 degree celcius, Indirect injection (IDI) Fuel System, Ambient working temperature upto 55 degree celcius.
GOVERNING CLASS	"Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient) "	15

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	"Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient) "	15.0 <b>(second)</b>
	Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Permanent)	5
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient) "	4
	"Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) "	5.0 <b>(second)</b>
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent)	1.5
ALTERNATOR	Alternator Voltage Rating	415.0 <b>(Volt)</b>
	Efficiency at rated Power factor at 75% of full Load	96.0 - 100.0 Or higher <b>(percent)</b>
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	<b>Voltage Regulation Grade</b>	VG 3 Or higher
	Alternator IP Rating	IP 23 Or higher
	Salient features of Alternator	NA
CONTROL PANEL	<b>Control Panel</b>	AMF Control Panel
	Control Panel Location	Outside the Canopy
	IP Rating of Control Panel	IP 55 Or higher
	Display meters in the control panel (with appropriate rating and accuracy class ) - inclusive in the scope of supply	Voltmeter, Ammeter, Frequency meter, Power Factor meter, Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor)
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Contactor, Circuit breaker, Battery charger, remote monitoring over internet with GSM modem.

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Displayed parameters/Features	Engine Speed, Lube oil pressure, Coolant/cylinder head Temperature, Engine running hours, Engine battery voltage, Engine Running status, Generator Voltage (Ph-Ph), Generator Voltage (Ph-N), Generator Current (R, Y, B), Generator apparent Power (kVA), Generator active Power (kW), Powerfactor, Frequency, Fuel level, Event log, Control supply Voltage
	Indicators	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
	Audio Alarm	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
ACOUSTIC ENCLOSURE	Sheet Thickness(mm)	1.6, 1.8, 2 Or higher
	Thickness of insulation	50.0 - 120.0 Or higher ( <b>millimeter</b> )
	Density of insulation (kg/cubic m)	64.0 - 100.0 Or higher
	Noise level at 1 meter (dB)	75
Fuel Tank	Fuel Tank Capacity	700.0, 850.0 ( <b>liter</b> )
	Number of Fuel tank	1
	Fuel Tank Sheet Material Thickness(mm)	2, 3 Or higher
	Fuel Tank Features	Fuel Tank capacity is sufficient for 8 hrs of running at full load
BATTERY	Battery Type & Specification	"Low Maintenance free to IS: 14257 for high cranking performance"
	Battery capacity (Ah)	180
	No of batteries	2
SALIENT FEATURES	Salient Features of Power Generator	Glass window on Accoustic Enclosure in front of the Control Panel, Emergency Stop outside the Accoustic Enclosure
TRAILER	<b>Trailer</b>	NA for Fixed/Skid Mounted Power Generator
	<b>Pay load of the Trailer</b>	0, 500, 1000, 2000 Or higher ( <b>kilogram</b> )
	Number of Axlels	0
	Number of wheels	'NA' for without trailer
	Wheel Tyre size	0.0 ( <b>inch</b> )
	Brakes	NA for Fixed/Skid Mounted Power Generator, Hydraulic, Electrical Or higher
	Trailer Complying to CMVR act and Regulation	NA for Fixed/Skid Mounted Power Generator
	Salient Features of trailer	NA
SCOPE OF INSTALLATION	<b>Installation</b>	with installation - inclusive in the scope of supply Or higher

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-3)	d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICE S	<b>Warranty on Complete power genertor/DG Set</b>	24, 36 Or higher <b>(month)</b>
	Warranty in running hours	5000.0 - 5000.0 Or higher <b>(hour)</b>
	<b>Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)*</b>	2
TEST REPORTS	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificates required as per CPCB
	<b>Test report Available for (Test/approval)</b>	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications
	Agree to provide all relevant documents Test Report/supporting document /reports etc to the buyer at the time of bidding or on demand	YES

परिषदी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषदी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	*****	*****HOSHANGABAD	1	120

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. **Generic**

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

Chief General Manager  
Ordnance Factory Itarsi  
A Unit of Munitions India Limited  
Dist- Narmadapuram  
Madhya Pradesh- 461122  
.

2. **Generic**

**Bidder financial standing:** The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

3. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

4. **Turnover**

Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

5. **Turnover**

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

6. **Purchase Preference (Centre)**

Purchase Preference linked with Local Content (PP-LC) Policy:

The bid clause regarding "Preference to Make In India products" stands modified in this bid and shall be

governed by the PPLC Policy No. FP-20013/2/2017-FP-PNG dated 17.11.2020 issued by MoP&NG as amended up to date. Accordingly, bidders with Local Content less than or equal to 20% will be treated as "Non Local Supplier". The prescribed LC shall be applicable on the date of Bid opening. Sanctions on the bidders for false / wrong declaration or not fulfilling the Local Content requirement shall be as per the PPLC policy. Further following additional provisions are added in the certification and verification of local content provision of the Preference to Make in India clause:

- i. In case of foreign bidder, certificate from the statutory auditor or cost auditor of their own office or subsidiary in India giving the percentage of local content is also acceptable. In case office or subsidiary in India does not exist or Indian office/subsidiary is not required to appoint statutory auditor or cost auditor, certificate from practicing cost accountant or practicing chartered accountant giving the percentage of local content is also acceptable.
- ii. Along with Each Invoice: The local content certificate (issued by statutory auditor on behalf of procuring company) shall be submitted along with each invoice raised. However, the % of local content may vary with each invoice while maintaining the overall % of local content for the total work/purchase of the pro-rata local content requirement. In case, it is not satisfied cumulatively in the invoices raised up to that stage, the supplier shall indicate how the local content requirement would be met in the subsequent stages.
- iii. The bidder shall submit an undertaking from the authorized signatory of bidder having the Power of Attorney along with the bid stating the bidder meets the mandatory minimum LC requirement and such undertaking shall become a part of the contract.

## **7. Warranty**

Warranty period of the supplied products shall be 2 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

## **8. Warranty**

Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

## **9. Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1. Bidder shall comply all clauses of technical specifications & OFI General Terms & Conditions in totality without any deviation, failing which offer will be rejected.
2. Past experience for supply of similar equipment: The Bidder should have supplied the DG Set 500 KVA to any Central Govt/State Govt Org./PSU/Public Listed Company within last Ten (10) financial years before Bid opening date. Bidder should also submit the copy of supply order, performance certificate/job completion Certificate against the submitted supply order. The bidder must also provide details such as contact number, e-mail and address of its customer to whom the firm had supplied the similar plant /Machine/ equipments.
3. Final inspection will be done at OFI as per bid terms & condition.
4. After receipt of the equipment at OFI a joint inspection will be conducted by buyer (user section) and seller before releasing amount payable on product delivery.
5. At the time of delivery of equipment the seller will submit the guarantee certificate and self-inspection of material, equipment systems sub assemblies etc.
6. Warranty period will be applicable as per Gem Bid documents or as offered by bidder, whichever is longer. Accordingly, validity of security deposit to be provided by the bidder.

7. In case of any dispute related to any clause of this bid, MIL procurement manual-2023 will be prevailed.

8. Apart from the make mentioned in the technical specification, the equivalent make also be acceptable.

9. Bidder has to comply the Delivery Period, EMD, ePBG, Liquidity Damage (L.D.) Clause, Payment term, warranty clauses as per the bid term & condition without any deviation. Failing to which offer will be rejected.

10. OEM Authorization dealer/ Trader are not eligible for EMD Exemption, MSE Purchase preference, etc as per MSE Policy 2012 and its amendment.

11. The bidder must comply the following [parameter:-](#)

a) **Salient Feature of Engine:-** Turbo Charged Engine, Direct injection fuel system, CRDI Fuel system, cold start up to (-20 degree C), No derating applicable up to 4500 above MSL of altitude at 25 degree C, Ambient working temperature up to 55 degree C.

b) **Display meter in the Control Panel ( with appropriate rating and accuracy class) inclusive in the scope of supply:-** Voltmeter, Frequency meter, Power Factor meter, Multi functional digital display meter ( displaying voltage, current, frequency, power factor and energy (KWH) consumed during DG-SET functioning.

c) **General Technical requirements (GRT)/Commissioning (part-5):-** Control Panel ( AMF), shall be equipped with suitable voltmeter, Ammeter, Frequency meter, Power Factor meter, Energy meter (these items can be alternatively supplied in one multifunctional digital display meter displaying with voltage, current, frequency, power factor, Energy (KWH) consumed during DG Set functioning, etc.) , Battery Charger, indicators, various switches and cut out /MCB/MCCB/Contractor/Circuit breaker for the DG Output of appropriate rating and accuracy class for better utility.

d) **Type of lab which carried out test of Complete product to prove the conformity of product as per specification:-** Certificate required as per CPCB/Govt.Lab/NABL Accredited Lab.

e) **Type of Alternator:-** Brushless

f) **Class of insulation of Alternator:-** H

g) **Class of Governor:-** A2 or Better

#### 10. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

### अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.

5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms

of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**