

बिड दस्तावेज़ / Bid Document

| बिड विवरण/Bid Details | |
|---|--|
| बिड बंद होने की तारीख/समय /Bid End Date/Time | 10-02-2026 13:00:00 |
| बिड खुलने की तारीख/समय /Bid Opening Date/Time | 10-02-2026 13:30:00 |
| बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date) | 30 (Days) |
| मंत्रालय/राज्य का नाम/Ministry/State Name | Tamil Nadu |
| विभाग का नाम/Department Name | Tamil Nadu Dairy Development Corporation Limited |
| संगठन का नाम/Organisation Name | Tamil Nadu Cooperative Milk Producers Federation L |
| कार्यालय का नाम/Office Name | Head Office |
| कुल मात्रा/Total Quantity | 2 |
| वस्तु श्रेणी /Item Category | Power Generator - DG Set (up to 900 KVA) (Q2) |
| बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years) | 7 Lakh (s) |
| एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover | No |
| स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover | No |
| विक्रेता से मांगे गए दस्तावेज़/Document required from seller | Experience Criteria,Past Performance,Bidder Turnover,OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid? | Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in) |
| बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension | 1 |

| बिड विवरण/Bid Details | |
|--|-----------------------------|
| दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended | 3 |
| ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count | 1 |
| विगत प्रदर्शन /Past Performance | 50 % |
| बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled | No |
| लागू आरसीएम/RCM Applicable | Yes |
| बिड का प्रकार/Type of Bid | Two Packet Bid |
| तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation | 5 Days |
| निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM) | No |
| मूल्यांकन पद्धति/Evaluation Method | Total value wise evaluation |
| मध्यस्थता खंड/Arbitration Clause | No |
| सुलह खंड/Mediation Clause | No |

ईएमडी विवरण/EMD Detail

| | |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

ईपीबीजी विवरण /ePBG Detail

| | |
|-------------------|----|
| आवश्यकता/Required | No |
|-------------------|----|

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

| | |
|---|----|
| एमएसई खरीद वरीयता/MSE Purchase Preference | No |
|---|----|

एमआईआई खरीद वरीयता/MII Purchase Preference

| | |
|--|----|
| एमआईआई खरीद वरीयता/MII Purchase Preference | No |
|--|----|

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

जीएसटी की धारा 9(3)/Section 9(3) Of GST

Where ever RCM is applicable, sellers (Regular GST registered seller who opted out of FCM , unregistered seller, seller registered under composition scheme)will be forced to put Zero GST and GST cess in their bids. Buyer will have liability of paying the GST and GST cess to the government on the specified rate mentioned by them in this Bid.

जीएसटी की धारा 9(3) / Section 9(3) Of GST

Where ever RCM is applicable, sellers (Regular GST registered seller who opted out of FCM , unregistered seller, seller registered under composition scheme)will be forced to put Zero GST and GST cess in their bids. Buyer will have liability of paying the GST and GST cess to the government on the specified rate mentioned by them in this Bid.

If the buyer has mentioned MSE purchase preference in ATC then service provider is required to upload necessary documents for MSE purchase preference for verification by the buyer during evaluation.

Power Generator - DG Set (up To 900 KVA) (2 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---|---|--|
| Power Generator INSTALLATION CONFIGURATIONS | Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set) | Fixed (Power Generators are permanently installed)" |
| OUTPUT CAPACITY RATING/ PHASE | Nominal Rated Capacity (kVA) | 25 |
| ENGINE | Rated Engine Power (kWm) | 100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator + Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency, 110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency Or higher |
| | Type of governer | Electronic Or higher |

| विवरण/Specification | विशिष्टि का नाम /Specification Name | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|-----------------------|---|--|
| | Rated RPM of Engine (RPM) | 1500 |
| | Fuel | High Speed Diesel (HSD) |
| ALTERNATOR | Voltage Regulation Grade | VG 3 Or higher |
| CONTROL PANEL | Control Panel | Manual Control Panel |
| TRAILER | Trailer | NA for Fixed/Skid Mounted Power Generator |
| | Pay load of the Trailer | 0, 500, 1000, 2000 Or higher (kilogram) |
| SCOPE OF INSTALLATION | Installation | Without installation, with installation - inclusive in the scope of supply Or higher |
| WARRANTY/SERVICE S | Warranty on Complete power genertor/DG Set | 24, 36 Or higher (month) |
| | Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibility)* | 1 |
| TEST REPORTS | Test report Available for (Test/approval) | Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications |

Additional Specification Parameters - Power Generator - DG Set (up To 900 KVA) (2 pieces)

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|-------------------------------------|--|
| Trolley Mounting and Preferred Make | 1.. The Generator set shall be mounted rigidly on a trolley and shall be for easy movement. 2. The wheels shall have locking arrangements. 3. The trolley shall have the provision to connect / toe with Light vehicle for movement to the various locations. KRISLOSKAR / CUMMINS / ASHOK LEYLAND / GREAVES / MAHENDRA Note: Any other make will not be accepted. |
| Terms & Conditions: | 1. The supplier should be a OEM or Authorized Distributor or Dealer with OEM. 2. The supplier should have supplied same quantity and same 25 KVA DG as specified above to any of the DCMPU's or TCMPF Ltd. (AAVIN) specification of the material and should submit document for the same. 3. The supplier should be responsible for Supply, Erection and Commissioning of the DG in the below detailed sites in Tiruvannamalai District. |

| Specification Parameter Name | Bid Requirement (Allowed Values) |
|-------------------------------------|--|
| Terms & Conditions: 1 | 4. The supplier should be responsible for providing any necessary civil, wiring and earthing work at the site based on the site requirement including materials like cables, wires, clamps, pipes and tags etc wherever required. 5. The supplier should be responsible for dismantling the existing DG at the site and transporting back to Tiruvannamalai DCMPU Scrap yard Vengikal, Tiruvannamalai. |
| Terms & Conditions: 2 | 6. Based on the site condition the trolley arrangement can be modified and may not be provided as per site condition. 7. The supplier should make necessary arrangements for uninterrupted operations of the BMC while carrying out the above detailed work. |
| Terms & Conditions: 3 | 8. Any equipment related to erection and commissioning like JCB, Crane, Vehicles and other Drilling, Grinding, Breaking, etc should be arranged by the supplier. 9. Any communications regarding interruption in operation of the BMC should be communicated and prior permission should be obtained from The General manager, DGM P&I and Manager Engineering of Tiruvannamalai DCMPU |
| Trolley Mounting and Preferred Make | 1.. The Generator set shall be mounted rigidly on a trolley and shall be for easy movement. 2. The wheels shall have locking arrangements. 3. The trolley shall have the provision to connect / toe with Light vehicle for movement to the various locations. KRISLOSKAR / CUMMINS / ASHOK LEYLAND / GREAVES / MAHENDRA Note: Any other make will not be accepted. |
| Terms & Conditions: | 1. The supplier should be a OEM or Authorized Distributor or Dealer with OEM. 2. The supplier should have supplied same quantity and same 25 KVA DG as specified above to any of the DCMPU's or TCMPF Ltd. (AAVIN) specification of the material and should submit document for the same. 3. The supplier should be responsible for Supply, Erection and Commissioning of the DG in the below detailed sites in Tiruvannamalai District. |
| Terms & Conditions: 1 | 4. The supplier should be responsible for providing any necessary civil, wiring and earthing work at the site based on the site requirement including materials like cables, wires, clamps, pipes and tags etc wherever required. 5. The supplier should be responsible for dismantling the existing DG at the site and transporting back to Tiruvannamalai DCMPU Scrap yard Vengikal, Tiruvannamalai. |
| Terms & Conditions: 2 | 6. Based on the site condition the trolley arrangement can be modified and may not be provided as per site condition. 7. The supplier should make necessary arrangements for uninterrupted operations of the BMC while carrying out the above detailed work. |
| Terms & Conditions: 3 | 8. Any equipment related to erection and commissioning like JCB, Crane, Vehicles and other Drilling, Grinding, Breaking, etc should be arranged by the supplier. 9. Any communications regarding interruption in operation of the BMC should be communicated and prior permission should be obtained from The General manager, DGM P&I and Manager Engineering of Tiruvannamalai DCMPU |

* Bidders offering must also comply with the additional specification parameters mentioned above.

उपरोक्त मद के लिए इंस्टॉलेशन कमीशनिंग एंड टेस्टिंग (आईसीटी) का विवरण / Installation Commissioning and Testing (ICT) details for the above item:

| | |
|--|-----|
| % of Product Cost Payable on Product Delivery | 80% |
| Min Cost Allocation for ICT as a % of product cost | 20% |

| | |
|---|---------|
| Number of days allowed for ICT after site readiness communication to seller | 45 Days |
| GST as per RCM | 18% |
| GST Cess 1 as per RCM | 0% |
| Optional RCM | No |

इनपुट कर क्रेडिट(आईटीसी) तथा रिवर्स प्रभार (आरसीएम)/Input Tax Credit(ITC) and Reverse Charge(RCM) Details

| जीएसटी पर इनपुट कर क्रेडिट /ITC on GST | जीएसटी उपकर कर क्रेडिट /ITC on GST Cess | लागू आरसीएम/RCM Applicable | रिवर्स प्रभार के अनुसार जीएसटी/GST as per RCM | रिवर्स प्रभार के अनुसार जीएसटी उपकर 1 /GST Cess 1 as per RCM | GST Cess 2 as per RCM | वैकल्पिक रिवर्स प्रभार /Optional RCM |
|--|---|----------------------------|---|--|-----------------------|--------------------------------------|
| NA | NA | Yes | 18% | NA | NA | No |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.No. | परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer | पता/Address | मात्रा /Quantity | डिलीवरी के दिन/Delivery Days |
|---------------|---|--|------------------|------------------------------|
| 1 | V M Vinoth Kumar | 606604,Near Collector Office, Vengikkal, Thiruvannamalai | 2 | 30 |

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be (Increased quantity ÷ Original quantity) × Original delivery period (in days), subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Generic

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

Tiruvannamalai DCMPU Ltd
Polur Road
Near Collectorate
Vengikal
Tiruvannamalai 606604

3. Generic

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

4. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---